



**SUPPLY, DELIVERY,  
INSTALLATION, TESTING  
AND COMMISSIONING  
OF 43 UNITS  
GENERATOR SETS FOR  
PORT MANAGEMENT  
OFFICES (PMOs)**

**BID DOCS  
BAC-PGCS-029-2022**

## Table of Contents

Glossary of Acronyms, Terms, and Abbreviations.....	3
Section I. Invitation to Bid.....	6
Section II. Instructions to Bidders.....	9
1. Scope of Bid.....	10
2. Funding Information.....	10
3. Bidding Requirements.....	10
4. Corrupt, Fraudulent, Collusive, and Coercive Practices.....	10
5. Eligible Bidders.....	10
6. Origin of Goods.....	11
7. Subcontracts.....	11
8. Pre-Bid Conference.....	11
9. Clarification and Amendment of Bidding Documents.....	11
10. Documents comprising the Bid: Eligibility and Technical Components.....	11
11. Documents comprising the Bid: Financial Component.....	12
12. Bid Prices.....	12
13. Bid and Payment Currencies.....	13
14. Bid Security.....	13
15. Sealing and Marking of Bids.....	13
16. Deadline for Submission of Bids.....	13
17. Opening and Preliminary Examination of Bids.....	14
18. Domestic Preference.....	14
19. Detailed Evaluation and Comparison of Bids.....	14
20. Post-Qualification.....	15
21. Signing of the Contract.....	15
Section III. Bid Data Sheet.....	16
Section IV. General Conditions of Contract.....	18
1. Scope of Contract.....	19
2. Advance Payment and Terms of Payment.....	19
3. Performance Security.....	19
4. Inspection and Tests.....	19
5. Warranty.....	20
6. Liability of the Supplier.....	20
Section V. Special Conditions of Contract.....	21
Section VI. Schedule of Requirements.....	26
Section VII. Technical Specifications.....	27
Section VIII. Checklist of Technical and Financial Documents.....	50
<b>Section IX. Bidding Forms .....</b>	<b>53</b>

# **Glossary of Acronyms, Terms, and Abbreviations**

**ABC** – Approved Budget for the Contract.

**BAC** – Bids and Awards Committee.

**Bid** – A signed offer or proposal to undertake a contract submitted by a bidder in response to and in consonance with the requirements of the bidding documents. Also referred to as *Proposal* and *Tender*. (2016 revised IRR, Section 5[c])

**Bidder** – Refers to a contractor, manufacturer, supplier, distributor and/or consultant who submits a bid in response to the requirements of the Bidding Documents. (2016 revised IRR, Section 5[d])

**Bidding Documents** – The documents issued by the Procuring Entity as the bases for bids, furnishing all information necessary for a prospective bidder to prepare a bid for the Goods, Infrastructure Projects, and/or Consulting Services required by the Procuring Entity. (2016 revised IRR, Section 5[e])

**BIR** – Bureau of Internal Revenue.

**BSP** – Bangko Sentral ng Pilipinas.

**Consulting Services** – Refer to services for Infrastructure Projects and other types of projects or activities of the GOP requiring adequate external technical and professional expertise that are beyond the capability and/or capacity of the GOP to undertake such as, but not limited to: (i) advisory and review services; (ii) pre-investment or feasibility studies; (iii) design; (iv) construction supervision; (v) management and related services; and (vi) other technical services or special studies. (2016 revised IRR, Section 5[i])

**CDA** - Cooperative Development Authority.

**Contract** – Refers to the agreement entered into between the Procuring Entity and the Supplier or Manufacturer or Distributor or Service Provider for procurement of Goods and Services; Contractor for Procurement of Infrastructure Projects; or Consultant or Consulting Firm for Procurement of Consulting Services; as the case may be, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.

**CIF** – Cost Insurance and Freight.

**CIP** – Carriage and Insurance Paid.

**CPI** – Consumer Price Index.

**DDP** – Refers to the quoted price of the Goods, which means “delivered duty paid.”

**DTI** – Department of Trade and Industry.

**EXW** – Ex works.

**FCA** – “Free Carrier” shipping point.

**FOB** – “Free on Board” shipping point.

**Foreign-funded Procurement or Foreign-Assisted Project**– Refers to procurement whose funding source is from a foreign government, foreign or international financing institution as specified in the Treaty or International or Executive Agreement. (2016 revised IRR, Section 5[b]).

**Framework Agreement** – Refers to a written agreement between a procuring entity and a supplier or service provider that identifies the terms and conditions, under which specific purchases, otherwise known as “Call-Offs,” are made for the duration of the agreement. It is in the nature of an option contract between the procuring entity and the bidder(s) granting the procuring entity the option to either place an order for any of the goods or services identified in the Framework Agreement List or not buy at all, within a minimum period of one (1) year to a maximum period of three (3) years. (GPPB Resolution No. 27-2019)

**GFI** – Government Financial Institution.

**GOCC** – Government-owned and/or –controlled corporation.

**Goods** – Refer to all items, supplies, materials and general support services, except Consulting Services and Infrastructure Projects, which may be needed in the transaction of public businesses or in the pursuit of any government undertaking, project or activity, whether in the nature of equipment, furniture, stationery, materials for construction, or personal property of any kind, including non-personal or contractual services such as the repair and maintenance of equipment and furniture, as well as trucking, hauling, janitorial, security, and related or analogous services, as well as procurement of materials and supplies provided by the Procuring Entity for such services. The term “related” or “analogous services” shall include, but is not limited to, lease or purchase of office space, media advertisements, health maintenance services, and other services essential to the operation of the Procuring Entity. (2016 revised IRR, Section 5[r])

**GOP** – Government of the Philippines.

**GPPB** – Government Procurement Policy Board.

**INCOTERMS** – International Commercial Terms.

**Infrastructure Projects** – Include the construction, improvement, rehabilitation, demolition, repair, restoration or maintenance of roads and bridges, railways, airports, seaports, communication facilities, civil works components of information technology projects, irrigation, flood control and drainage, water supply, sanitation, sewerage and solid waste management systems, shore protection, energy/power and electrification facilities, national buildings, school buildings, hospital buildings, and other related construction projects of the government. Also referred to as *civil works or works*. (2016 revised IRR, Section 5[u])

**LGUs** – Local Government Units.

**NFCC** – Net Financial Contracting Capacity.

**NGA** – National Government Agency.

**PhilGEPS** - Philippine Government Electronic Procurement System.

**Procurement Project** – refers to a specific or identified procurement covering goods, infrastructure project or consulting services. A Procurement Project shall be described, detailed, and scheduled in the Project Procurement Management Plan prepared by the agency which shall be consolidated in the procuring entity's Annual Procurement Plan. (GPPB Circular No. 06-2019 dated 17 July 2019)

**PSA** – Philippine Statistics Authority.

**SEC** – Securities and Exchange Commission.

**SLCC** – Single Largest Completed Contract.

**Supplier** – refers to a citizen, or any corporate body or commercial company duly organized and registered under the laws where it is established, habitually established in business and engaged in the manufacture or sale of the merchandise or performance of the general services covered by his bid. (Item 3.8 of GPPB Resolution No. 13-2019, dated 23 May 2019). Supplier as used in these Bidding Documents may likewise refer to a distributor, manufacturer, contractor, or consultant.

**UN** – United Nations.



## **INVITATION TO BID**

### **FOR THE SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF 43 UNITS GENERATOR SETS FOR PORT MANAGEMENT OFFICES (PMOs)**

The Philippine Ports Authority, through the Corporate Budget of the Authority for CY 2022, intends to apply the sum of **P422,667,120.00** being the Approved Budget for the Contract (ABC) to payments under the contract for the Supply, Delivery, Installation, Testing and Commissioning of 43 Units Generator Sets for Port Management Offices (PMOs) (BAC PGCS-029-2022 Early Procurement)). Bids received in excess of the ABC shall be automatically rejected at bid opening.

The Philippine Ports Authority now invites bids for the above Procurement Project. Completion of the Services is required within One Hundred Fifty (150) calendar days from receipt of the Notice to Proceed by the winning bidder subject to the following schedule a) Supply, delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for PMOs – Delivery at warehouse within Metro Manila (for inspection of PPA Head Office representatives) within ninety (90) calendar days b) Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for PMOs – Delivery, Installation, testing and commissioning at the PMOs within sixty (60) calendar days after inspection and acceptance by PPA Head Office representatives. Bidders should have completed, within five (5) years from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).

Bidding will be conducted through open competitive bidding procedures using a non-discretionary "pass/fail" criterion as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) 9184. Bidding is restricted to Filipino citizens/sole proprietorships, partnerships, or organizations with at least sixty percent (60%) interest or outstanding capital stock belonging to citizens of the Philippines, and to citizens or organizations of a country the laws or regulations of which grant similar rights or privileges to Filipino citizens, pursuant to RA 5183.

Prospective Bidders may obtain further information from the Philippine Ports Authority Bids and Awards Committee (BAC) and inspect the Bidding Documents at the address given below during 8:00 a.m. to 5:00 p.m., Monday to Friday.

A complete set of Bidding Documents may be acquired by interested Bidders on **21 February 2022** from the given address and website(s) below and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of **Fifty Thousand (P50,000.00) Pesos**. The Procuring Entity shall allow the bidder to present its proof of payment for the fees in person.

The Philippine Ports Authority's Bids and Awards Committee will hold a Pre-Bid Conference on **02 March 2022 at 2:00 p.m.** at the PPA Function Room, 7th Floor, PPA Bldg., Bonifacio Drive, South Harbor, Port Area, Manila, and/or through video conferencing or webcasting via zoom, which shall be open to all prospective bidders.

Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before **16 March 2022 at 9:00 a.m.** Late bids shall not be accepted.


All Bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in ITB Clause 14.

Bid opening shall be on **16 March 2022 at 10:00 a.m.** at the 7th Floor, PPA Building, A. Bonifacio Drive, South Harbor, Port Area, Manila. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.

The Philippine Ports Authority reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.

For further information, please refer to:

BAC Secretariat, Philippine Ports Authority  
5th Floor, PPA Bldg., A. Bonifacio Drive,  
South Harbor, Port Area, Manila  
Telephone Nos. 527-47-35  
527-83-56 to 83 loc. 539  
PPA Website: [www.ppa.com.ph](http://www.ppa.com.ph)  
PhilGEPS Website: [www.philgeps.gov.ph](http://www.philgeps.gov.ph)



**MARK JON S. PALOMAR**  
Chairperson, PPA Head Office Bids and Awards  
Committee for the Procurement of Goods and  
Consultancy Services (HO-BAC-PGCS)

## ***Section II. Instructions to Bidders***

## **1. Scope of Bid**

The Procuring Entity, PHILIPPINE PORTS AUTHORITY wishes to receive Bids for the **Supply, Delivery, Installation, Testing and Commissioning of 43 Units Generator Sets for PPA Port Management Offices (PMOs)** with identification number **BAC-PGCS-029-2022**.

The Procurement Project (referred to herein as “Project”) is composed of two (2) lots, the details of which are described in Section VII (Technical Specifications).

## **2. Funding Information**

2.1. The Philippine Ports Authority through its corporate budget for the Calendar Year (CY) 2022 in the amount of **Four Hundred Twenty Two Million Six Hundred Sixty Seven Thousand One Hundred Twenty Pesos (Php 422,667,120.00)**.

2.2. The source of funding is the Corporate Budget of the PHILIPPINE PORTS AUTHORITY.

## **3. Bidding Requirements**

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manuals and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or **IB** by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have verified and accepted the general requirements of this Project, including other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

## **4. Corrupt, Fraudulent, Collusive, and Coercive Practices**

The Procuring Entity, as well as the Bidders and Suppliers, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex “I” of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

## **5. Eligible Bidders**

5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.

- 5.2 Foreign ownership limited to those allowed under the rules may participate in this Project.
- 5.3. Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, must be at least equivalent to at least fifty percent (50%) of the ABC.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.1 of the 2016 IRR of RA No. 9184.

## **6. Origin of Goods**

There is no restriction on the origin of goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN, subject to Domestic Preference requirements under ITB Clause 18.

## **7. Subcontracts**

- 7.1 The Bidder may subcontract portions of the Project to the extent allowed by the Procuring Entity as stated herein, but in no case more than twenty percent (20%) of the Project.

The Procuring Entity has prescribed that:

Subcontracting is not allowed.

## **8. Pre-Bid Conference**

The Procuring Entity will hold a Pre-Bid conference for this Project on the specified date and time and either at its physical address at the PPA Function Room, 7<sup>th</sup> Floor, PPA Building, Bonifacio Drive, South Harbor, Port Area, Manila and/or through videoconferencing/webcasting as indicated in paragraph 6 of the IB.

## **9. Clarification and Amendment of Bidding Documents**

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the IB, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

## **10. Documents comprising the Bid: Eligibility and Technical Components**

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in Section VIII (Checklist of Technical and Financial Documents).
- 10.2. The Bidder's SLCC as indicated in ITB Clause 5.3 should have been completed within five (5) years prior to the deadline for the submission and receipt of bids.

- 10.3. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. Similar to the required authentication above, for Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.

## **11. Documents comprising the Bid: Financial Component**

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section VIII (Checklist of Technical and Financial Documents)**.
- 11.2. If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a certification issued by DTI shall be provided by the Bidder in accordance with Section 43.1.3 of the 2016 revised IRR of RA No. 9184.
- 11.3. Any bid exceeding the ABC indicated in paragraph 1 of the IB shall not be accepted.
- 11.4. For Foreign-funded Procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

## **12. Bid Prices**

- 12.1. Prices indicated on the Price Schedule shall be entered separately in the following manner:
- a. For Goods offered from within the Procuring Entity's country:
    - i. The price of the Goods quoted EXW (ex-works, ex-factory, ex-warehouse, ex-showroom, or off-the-shelf, as applicable);
    - ii. The cost of all customs duties and sales and other taxes already paid or payable;
    - iii. The cost of transportation, insurance, and other costs incidental to delivery of the Goods to their final destination; and
    - iv. The price of other (incidental) services, if any, listed in e.
  - b. For Goods offered from abroad:
    - i. Unless otherwise stated in the BDS, the price of the Goods shall be quoted delivered duty paid (DDP) with the place of destination

in the Philippines as specified in the **BDS**. In quoting the price, the Bidder shall be free to use transportation through carriers registered in any eligible country. Similarly, the Bidder may obtain insurance services from any eligible source country.

- ii. The price of other (incidental) services, if any, as listed in **Section VII (Technical Specifications)**.

### **13. Bid and Payment Currencies**

13.1. For Goods that the Bidder will supply from outside the Philippines, the bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies, shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.

13.2. Payment of the contract price shall be made in Philippine Pesos.

### **14. Bid Security**

14.1. The Bidder shall submit a Bid Securing Declaration or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.

14.2. The Bid and bid security shall be valid for One Hundred Twenty (120) calendar days from the date of the opening of bids. Any Bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

### **15. Sealing and Marking of Bids**

Each bidder shall submit one copy of the first and second components of the Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

### **16. Deadline for Submission of Bids**

16.1. The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

## **17. Opening and Preliminary Examination of Bids**

- 17.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

- 17.2. The preliminary examination of bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

## **18. Domestic Preference**

- 18.1. The Procuring Entity will grant a margin of preference for the purpose of comparison of Bids in accordance with Section 43.1.2 of the 2016 revised IRR of RA No. 9184.

## **19. Detailed Evaluation and Comparison of Bids**

- 19.1. The Procuring BAC shall immediately conduct a detailed evaluation of all Bids rated "*passed*," using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of the 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, bidders may submit a proposal on any of the lots or items, and evaluation will be undertaken on a per lot or item basis, as the case maybe. In this case, the Bid Security as required by **ITB** Clause 15 shall be submitted for each lot or item separately.
- 19.3. The descriptions of the lots or items shall be indicated in **Section VII (Technical Specifications)**, although the ABCs of these lots or items are indicated in the **BDS** for purposes of the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184. The NFCC must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder.
- 19.4. The Project shall be awarded as one Project having several items that shall be awarded as one contract.
- 19.5. Except for bidders submitting a committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation, all Bids must include the NFCC computation pursuant to Section 23.4.1.4 of the 2016 revised IRR of RA No. 9184, which must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder. For bidders submitting the committed Line of Credit, it must be at least equal to ten percent (10%) of the ABCs for all the lots or items participated in by the prospective Bidder.

## **20. Post-Qualification**

- 20.1. Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) and other appropriate licenses and permits required by law and stated in the **BDS**.

## **21. Signing of the Contract**

- 21.1. The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

## Bid Data Sheet

ITB Clause	
5.3	<p>For this purpose, contracts similar to the Project shall be:</p> <ul style="list-style-type: none"> <li>a. Supply, Delivery, Installation and Commissioning of Generator Sets.</li> <li>b. completed within five (5) years prior to the deadline for the submission and receipt of bids.</li> </ul>
7.1	Subcontracting is not allowed.
12	The price of the Goods shall be quoted DDP <i>[Manila]</i> or the applicable International Commercial Terms (INCOTERMS) for this Project.
14.1	<p>The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts:</p> <ul style="list-style-type: none"> <li>a. The amount of not less than Eight Million Four Hundred Fifty Three Thousand Three Hundred Forty Two Pesos and 40/100 (Php8,453,342.40), if bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit; or</li> <li>b. The amount of not less than Twenty One Million One Hundred Thirty Three Thousand Three Hundred Fifty Six Pesos (Php21,133,356.00) if bid security is in Surety Bond.</li> </ul>
15	<p>Each Bidder shall submit <b>ONE (1) original and SIX (6) copies</b> of its Technical and Financial Components of its Bid in two (2) separate sealed bid envelopes, which should be submitted simultaneously. Each of the bid documents should be individually sealed.</p> <p>All bid documents shall be book-bound with hard cover and properly labelled with index tabs. Failure to comply with the said requirements is a ground for automatic disqualification of the bidder.</p>
19.3	Partial bid is not allowed. The goods are grouped in a single lot and the lot shall not be divided into sub-lots for the purpose of bidding, evaluation, and contract award.
20.1	No additional requirements.
21.1	No additional requirements.

## ***Section IV. General Conditions of Contract***

## **1. Scope of Contract**

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

Additional requirements for the completion of this Contract shall be provided in the **Special Conditions of Contract (SCC)**.

## **2. Advance Payment and Terms of Payment**

- 2.1. Advance payment of the contract amount is provided under Annex "D" of the revised 2016 IRR of RA No. 9184.
- 2.2. The Procuring Entity is allowed to determine the terms of payment on the partial or staggered delivery of the Goods procured, provided such partial payment shall correspond to the value of the goods delivered and accepted in accordance with prevailing accounting and auditing rules and regulations. The terms of payment are indicated in the SCC.

## **3. Performance Security**

Within ten (10) calendar days from receipt of the Notice of Award by the Bidder from the Procuring Entity but in no case later than prior to the signing of the Contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR of RA No. 9184.

## **4. Inspection and Tests**

The Procuring Entity or its representative shall have the right to inspect and/or to test the Goods to confirm their conformity to the Project specifications at no extra cost to the Procuring Entity in accordance with the Generic Procurement Manual. In addition to tests in the SCC, **Section IV (Technical Specifications)** shall specify what inspections and/or tests the Procuring Entity requires, and where they are to be conducted. The Procuring Entity shall notify the Supplier in writing, in a timely manner, of the identity of any representatives retained for these purposes.

All reasonable facilities and assistance for the inspection and testing of Goods, including access to drawings and production data, shall be provided by the Supplier to the authorized inspectors at no charge to the Procuring Entity.

## **5. Warranty**

- 6.1. In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier as provided under Section 62.1 of the 2016 revised IRR of RA No. 9184.
- 6.2. The Procuring Entity shall promptly notify the Supplier in writing of any claims arising under this warranty. Upon receipt of such notice, the Supplier shall, repair or replace the defective Goods or parts thereof without cost to the Procuring Entity, pursuant to the Generic Procurement Manual.

## **6. Liability of the Supplier**

The Supplier's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Supplier is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

## ***Section V. Special Conditions of Contract***

## Special Conditions of Contract

GCC Clause	
1	<p><b>Delivery and Documents –</b></p> <p>For purposes of the Contract, “EXW,” “FOB,” “FCA,” “CIF,” “CIP,” “DDP” and other trade terms used to describe the obligations of the parties shall have the meanings assigned to them by the current edition of INCOTERMS published by the International Chamber of Commerce, Paris. The Delivery terms of this Contract shall be as follows:</p> <p><i>[For Goods supplied from abroad, state:]</i> “The delivery terms applicable to the Contract are DDP delivered <i>[indicate place of destination]</i>. In accordance with INCOTERMS.”</p> <p><i>For Goods supplied from within the Philippines, state:]</i> “The delivery terms applicable to this Contract are delivered <i>[indicate place of destination]</i>. Risk and title will pass from the Supplier to the Procuring Entity upon receipt and final acceptance of the Goods at their final destination.”</p> <p>Delivery of the Goods shall be made by the Supplier in accordance with the terms specified in Section VI (Schedule of Requirements).</p> <p>For purposes of this Clause the Procuring Entity’s Representatives at the Project Site is Philippine Ports Authority – Head Office, Manila.</p> <p><b>Incidental Services –</b></p> <p>The Supplier is required to provide all of the following services, including additional services, if any, specified in Section VI. Schedule of Requirements:</p> <ol style="list-style-type: none"> <li>a. performance or supervision of on-site assembly and/or start-up of the supplied Goods;</li> <li>b. furnishing of tools required for assembly and/or maintenance of the supplied Goods;</li> <li>c. furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied Goods; and</li> <li>d. performance or supervision or maintenance and/or repair of the supplied Goods, for a period of time agreed by the parties, provided that this service shall not relieve the Supplier of any warranty obligations under this Contract.</li> </ol> <p>The Contract price for the Goods shall include the prices charged by the Supplier for incidental services and shall not exceed the prevailing rates charged to other parties by the Supplier for similar services.</p> <p><b>Spare Parts –</b></p>

The Supplier is required to provide all of the following materials, notifications, and information pertaining to spare parts manufactured or distributed by the Supplier:

- a. such spare parts as the Procuring Entity may elect to purchase from the Supplier, provided that this election shall not relieve the Supplier of any warranty obligations under this Contract; and
- b. in the event of termination of production of the spare parts:
  - i. advance notification to the Procuring Entity of the pending termination, in sufficient time to permit the Procuring Entity to procure needed requirements; and
  - ii. following such termination, furnishing at no cost to the Procuring Entity, the blueprints, drawings, and specifications of the spare parts, if requested.

The spare parts and other components required are listed in **Section VI (Schedule of Requirements)** and the cost thereof are included in the contract price.

The Supplier shall carry sufficient inventories to assure ex-stock supply of consumable spare parts or components for the Goods for a period of at least five (5) years from the purchase of the subject units.

Spare parts or components shall be supplied as promptly as possible, but in any case, within two (2) months of placing the order.

**Packaging –**

The Supplier shall provide such packaging of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in this Contract. The packaging shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit, and open storage. Packaging case size and weights shall take into consideration, where appropriate, the remoteness of the Goods' final destination and the absence of heavy handling facilities at all points in transit.

The packaging, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract, including additional requirements, if any, specified below, and in any subsequent instructions ordered by the Procuring Entity.

The outer packaging must be clearly marked on at least four (4) sides as follows:

Name of the Procuring Entity  
Name of the Supplier  
Contract Description  
Final Destination

	<p>Gross weight Any special lifting instructions Any special handling instructions Any relevant HAZCHEM classifications</p> <p>A packaging list identifying the contents and quantities of the package is to be placed on an accessible point of the outer packaging if practical. If not practical the packaging list is to be placed inside the outer packaging but outside the secondary packaging.</p> <p><b>Transportation –</b></p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP, or DDP, transport of the Goods to the port of destination or such other named place of destination in the Philippines, as shall be specified in this Contract, shall be arranged and paid for by the Supplier, and the cost thereof shall be included in the Contract Price.</p> <p>Where the Supplier is required under this Contract to transport the Goods to a specified place of destination within the Philippines, defined as the Project Site, transport to such place of destination in the Philippines, including insurance and storage, as shall be specified in this Contract, shall be arranged by the Supplier, and related costs shall be included in the contract price.</p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP or DDP, Goods are to be transported on carriers of Philippine registry. In the event that no carrier of Philippine registry is available, Goods may be shipped by a carrier which is not of Philippine registry provided that the Supplier obtains and presents to the Procuring Entity certification to this effect from the nearest Philippine consulate to the port of dispatch. In the event that carriers of Philippine registry are available but their schedule delays the Supplier in its performance of this Contract the period from when the Goods were first ready for shipment and the actual date of shipment the period of delay will be considered force majeure.</p> <p>The Procuring Entity accepts no liability for the damage of Goods during transit other than those prescribed by INCOTERMS for DDP deliveries. In the case of Goods supplied from within the Philippines or supplied by domestic Suppliers risk and title will not be deemed to have passed to the Procuring Entity until their receipt and final acceptance at the final destination.</p> <p><b>Intellectual Property Rights –</b></p> <p>The Supplier shall indemnify the Procuring Entity against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof.</p>
2.2	The terms of payment shall be as follows:

	<p>a.) 70% of contract cost – After inspection and acceptance by Head Office.</p> <p>b.) 30% of contract cost – After installation, testing, commissioning, inspection and acceptance by PMOs.</p>
4	The equipment shall be tested (on/off and running for at least 10 minutes) after installation to the respective PMOs as per deployment list.

## ***Section VI. Schedule of Requirements***

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

<b>Item Number</b>	<b>Description<sup>1</sup></b>	<b>Quantity</b>	<b>Total</b>	<b>Delivered, Weeks/Months</b>
	<p>Supply, Delivery, Installation, Testing and Commissioning of 43 Units Generator Sets for Port Management Offices (PMOs) with the following components:</p> <p>1. Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for PMOs; and</p> <p>2. Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for PMOs</p>			<p>Within One Hundred Fifty (150) calendar days from receipt of the Notice to Proceed subject to the following schedule:</p> <p>a) Delivery at warehouse within Metro Manila (for inspection of PPA Head Office representatives) within ninety (90) calendar days</p> <p>b) Delivery, installation, testing and commissioning at the PMOs within sixty (60) calendar days after inspection and acceptance by PPA Head Office representatives.</p>

<sup>1</sup> Subject to the Technical Specifications and Deployment Schedule under Items V and III, respectively, of the Terms of Reference.

## ***Section VII. Technical Specifications***

## Technical Specifications

Item	Specification	Statement of Compliance
		<p><i>[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A</i></p>

		<p><i>statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i></p>
	<p><b>SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF 43 UNITS GENERATOR SETS FOR PORT MANAGEMENT OFFICES (PMOs), WITH THE FOLLOWING COMPONENTS:</b></p>	

	<div>1. Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for PMOs; and</div> <div>2. Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for PMOs</div>																																																																																	
	<div>SCOPE OF WORK</div> <div>1. Supply and delivery of the brand new generator sets and Automatic Transfer Switch (ATS).</div> <div>2. Mobilization of manpower, equipment and technical supervisions.</div> <div>3. Installation of the equipment at the designated deployment ports.</div> <div>4. Testing and commissioning of the equipment per port or terminal.</div>																																																																																	
	<div>DEPLOYMENT:</div> <div>1. Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices:</div> <table><tr><th colspan="5">Generator Set Requirements</th></tr><tr><th></th><th>PMO</th><th>Capacity</th><th>Qty.</th><th>Deployment</th></tr><tr><td>1</td><td>NCR NORTH</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>2</td><td>NCR SOUTH</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>3</td><td>Bataan/Aurora</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>4</td><td>Northern Luzon</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>5</td><td>Batangas</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>6</td><td>Bicol</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>7</td><td>Palawan</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>8</td><td>Mindoro</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>9</td><td>Marinduque/Quezon</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>10</td><td>Masbate</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>11</td><td>Negros Oriental/Siquijor</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>12</td><td>Panay Guimaras</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>13</td><td>Eastern Leyte/Samar</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr><tr><td>14</td><td>Negros Occidental/Bacolod/Banago/Bredco</td><td>50 KVA, Single Phase</td><td>1</td><td>Baseport</td></tr></table>	Generator Set Requirements						PMO	Capacity	Qty.	Deployment	1	NCR NORTH	50 KVA, Single Phase	1	Baseport	2	NCR SOUTH	50 KVA, Single Phase	1	Baseport	3	Bataan/Aurora	50 KVA, Single Phase	1	Baseport	4	Northern Luzon	50 KVA, Single Phase	1	Baseport	5	Batangas	50 KVA, Single Phase	1	Baseport	6	Bicol	50 KVA, Single Phase	1	Baseport	7	Palawan	50 KVA, Single Phase	1	Baseport	8	Mindoro	50 KVA, Single Phase	1	Baseport	9	Marinduque/Quezon	50 KVA, Single Phase	1	Baseport	10	Masbate	50 KVA, Single Phase	1	Baseport	11	Negros Oriental/Siquijor	50 KVA, Single Phase	1	Baseport	12	Panay Guimaras	50 KVA, Single Phase	1	Baseport	13	Eastern Leyte/Samar	50 KVA, Single Phase	1	Baseport	14	Negros Occidental/Bacolod/Banago/Bredco	50 KVA, Single Phase	1	Baseport	
Generator Set Requirements																																																																																		
	PMO	Capacity	Qty.	Deployment																																																																														
1	NCR NORTH	50 KVA, Single Phase	1	Baseport																																																																														
2	NCR SOUTH	50 KVA, Single Phase	1	Baseport																																																																														
3	Bataan/Aurora	50 KVA, Single Phase	1	Baseport																																																																														
4	Northern Luzon	50 KVA, Single Phase	1	Baseport																																																																														
5	Batangas	50 KVA, Single Phase	1	Baseport																																																																														
6	Bicol	50 KVA, Single Phase	1	Baseport																																																																														
7	Palawan	50 KVA, Single Phase	1	Baseport																																																																														
8	Mindoro	50 KVA, Single Phase	1	Baseport																																																																														
9	Marinduque/Quezon	50 KVA, Single Phase	1	Baseport																																																																														
10	Masbate	50 KVA, Single Phase	1	Baseport																																																																														
11	Negros Oriental/Siquijor	50 KVA, Single Phase	1	Baseport																																																																														
12	Panay Guimaras	50 KVA, Single Phase	1	Baseport																																																																														
13	Eastern Leyte/Samar	50 KVA, Single Phase	1	Baseport																																																																														
14	Negros Occidental/Bacolod/Banago/Bredco	50 KVA, Single Phase	1	Baseport																																																																														

15	Western Leyte/Biliran	50 KVA, Single Phase	1	Baseport
16	Bohol	50 KVA, Single Phase	1	Baseport
17	Misamis Oriental/Cagayan De Oro	50 KVA, Single Phase	1	Baseport
18	Lanao Del Norte/Iligan	50 KVA, Single Phase	1	Baseport
19	Misamis Occidental/Ozamiz	50 KVA, Single Phase	1	Baseport
20	Surigao	50 KVA, Single Phase	1	Baseport
21	Agusan	50 KVA, Single Phase	1	Baseport
22	SOCSARGEN	50 KVA, Single Phase	1	Baseport
23	Davao	50 KVA, Single Phase	1	Baseport
24	Zamboanga	50 KVA, Single Phase	1	Baseport
25	Zamboanga Del Norte	50 KVA, Single Phase	1	Baseport
<b>TOTAL NO. OF UNITS</b>			<b>25</b>	

**2. Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for Port Management Offices**

Generator Sets Requirements				
	PMO	Capacity	Qty.	Deployment
1	Mindoro	500 KVA, 3 Phase (with Synchronizer)	2	Baseport, Port of Calapan
2	Negros Oriental/Siquijor	150 KVA, 3 Phase	1	TMO Guihulngan
		150 KVA, 3 Phase	1	Port of Lazi
3	Eastern Leyte/Samar	150 KVA, 3 Phase	1	TMO Liloan
		100 KVA, 3 Phase	1	Port of San Ricardo
4	Negros Occidental/Bacolod/Banago/Bredco	150 KVA, 3 Phase	1	TMO San Carlos
5	Bohol	750 KVA, 3 Phase	1	Baseport, Port of Tagbilaran
		250 KVA, 3 Phase	1	TMO Jagna
		125 KVA, 3 Phase	1	TMO Talibon
		750 KVA, 3 Phase	1	TMO Tubigon
		125 KVA, 3 Phase	1	TMO Getafe
		125 KVA, 3 Phase	1	TMO Loon
6	Surigao	150 KVA, 3 Phase	1	Baseport, Port of Surigao
		100 KVA, 3 Phase	1	TMO Siargao
		100 KVA, 3 Phase	1	TMO Lipata
		50 KVA, 3 Phase	1	Port of Del Carmen
		25KVA, 3 Phase	1	Port of Sta. Monica
TOTAL NO. OF UNITS			18	

**TECHNICAL SPECIFICATIONS:**

**1. Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices:**

## **A. Mobile Generator Set**

### **50kVA Standby Power Mobile Generator Set**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	36.4kW/45.5kVA
Standby Rating Power (kW/kVA)	40kW/50kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	Single
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H) Fuel Tank Capacity	15.9L/H 160L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

## **B. Trailer and Enclosure**

- 1) Fork pockets
- 2) Interior Cabinet and Control Panel Lightning
- 3) 3-Point Contact, Deep ladder
- 4) Stacked Access Doors with Auto Shutdown
- 5) Large Service Doors
- 6) All Aluminum Enclosure
- 7) 110% Oil & Coolant Containment
- 8) Rear Controller Access
- 9) Easy-to-use controller
- 10) Diamond Anti-Skid Plating

	<b>11) LED Trailer Lighting</b>	
<b>TECHNICAL SPECIFICATIONS:</b>		
<b>2. Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for Port Management Offices:</b>		
<b>2.1 Two (2) Units 500KVA Prime Power Generator Set (with Synchronizer) - Baseport Port of Calapan, PMO Mindoro</b>		
Number of cylinders	6	
Cylinder arrangement	In-Line	
Aspiration	Turbocharged after-water cooling	
Prime Rating Power (kW/kVA)	400kW/500kVA	
Standby Rating Power (kW/kVA)	440kW/550kVA	
Control Panel	Digital	
Speed governor	Electronic	
Cooling system	Water Cooling Cycle	
Phase	3	
Rpm	1800	
Volts	230Vac	
Frequency	60hZ	
Power Factor	0.8	
Fuel consumption at 100% load (L/H)	104.1L/H	
Fuel Tank Capacity	850L	
Insulation	Class H	
Starter motor	24V	
Exciter type	Single bearing, Brushless, Self-excited	

**2.2 One (1) Unit 150KVA Prime Power Generator Set -  
Port of Guihulngan, PMO Negros Oriental/  
Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self- excited

**2.3 One (1) Unit 150KVA Prime Power Generator Set -  
Port of Lazi, PMO Negros Oriental/ Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H

	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
	<b>2.4 One (1) Unit 150KVA Prime Power Generator Set - Port of Liloan, PMO Eastern Leyte/Samar</b>		
	Number of cylinders	6	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after-water cooling	
	Prime Rating Power (kW/kVA)	120kW/150kVA	
	Standby Rating Power (kW/kVA)	132kW/165kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	34L/H	
	Fuel Tank Capacity	250L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
	<b>2.5 One (1) Unit 100KVA Prime Power Generator Set - Port of San Ricardo, PMO Eastern Leyte/Samar</b>		
	Number of cylinders	4	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after-water cooling	
	Prime Rating Power (kW/kVA)	80kW/100kVA	
	Standby Rating Power (kW/kVA)	88kW/110kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	

	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H) Fuel Tank Capacity	28.5L/H 150L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
<b>2.6 One (1) Unit 150KVA Prime Power Generator Set - Port of San Carlos, PMO Negros Occidental</b>			
	Number of cylinders	6	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after-water cooling	
	Prime Rating Power (kW/kVA)	120kW/150kVA	
	Standby Rating Power (kW/kVA)	132kW/165kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H) Fuel Tank Capacity	34L/H 250L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	

**2.7 One (1) Unit 750KVA Prime Power Generator Set -  
Baseport, Port of Tagbilaran, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	600kW/750kVA
Standby Rating Power (kW/kVA)	660kW/825kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	140L/H
Fuel Tank Capacity	1200L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**2.8 One (1) Unit 250KVA Prime Power Generator Set  
- Port of Jagna, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	200kW/250kVA
Standby Rating Power (kW/kVA)	220kW/275kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	59L/H
Fuel Tank Capacity	350L

	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
<b>2.9 One (1) Unit 125KVA Prime Power Generator Set - Port of Talibon, PMO Bohol</b>		
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	100kW/125kVA
	Standby Rating Power (kW/kVA)	110kW/137.5kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	29.7L/H
	Fuel Tank Capacity	210L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
<b>2.10 One (1) Unit 750KVA Prime Power Generator Set - Port of Tubigon, PMO Bohol</b>		
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	600kW/750kVA
	Standby Rating Power (kW/kVA)	660kW/825kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ

	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	140L/H	
	Fuel Tank Capacity	1200L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
	<b>2.11 One (1) Unit 125KVA Prime Power Generator Set - Port of Getafe, PMO Bohol</b>		
	Number of cylinders	6	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after-water cooling	
	Prime Rating Power (kW/kVA)	100kW/125kVA	
	Standby Rating Power (kW/kVA)	110kW/137.5kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	29.7L/H	
	Fuel Tank Capacity	210L	
	Insulation	Class H	
	Starter motor	24V	
Exciter type	Single bearing, Brushless, Self-excited		

**2.12 One (1) Unit 125KVA Prime Power Generator  
Set - Port of Loon, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	100kW/125kVA
Standby Rating Power (kW/kVA)	110kW/137.5kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H) Fuel Tank Capacity	29.7L/H 210L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**2.13 One (1) Unit 150KVA Prime Power Generator  
Set - Baseport Port of Surigao, PMO Surigao**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8

	Fuel consumption at 100% load (L/H) Fuel Tank Capacity	34L/H 250L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
<b>2.14 One (1) Unit 100KVA Prime Power Generator Set - Port of Siargao, PMO Surigao</b>		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	80kW/100kVA
	Standby Rating Power (kW/kVA)	88kW/110kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H) Fuel Tank Capacity	28.5L/H 150L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited

**2.15 One (1) Unit 100KVA Prime Power Generator Set - Port of Lipata, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	80kW/100kVA
Standby Rating Power (kW/kVA)	88kW/110kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	28.5L/H
Fuel Tank Capacity	150L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**2.16 One (1) Unit 50KVA Prime Power Generator Set - Port of Del Carmen, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	40kW/50kVA
Standby Rating Power (kW/kVA)	44kW/55kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8

	<table><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited																											
Fuel consumption at 100% load (L/H)	15.9L/H																																					
Fuel Tank Capacity	85L																																					
Insulation	Class H																																					
Starter motor	24V																																					
Exciter type	Single bearing, Brushless, Self-excited																																					
	<p><b>2.17 One (1) Unit 25KVA Prime Power Generator Set - Port of Sta. Monica, PMO Surigao</b></p> <table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>20kW/25kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>22kW/27.5kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60Hz</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>8.6L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	20kW/25kVA	Standby Rating Power (kW/kVA)	22kW/27.5kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	Rpm	1800	Volts	230Vac	Frequency	60Hz	Power Factor	0.8	Fuel consumption at 100% load (L/H)	8.6L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Number of cylinders	4																																					
Cylinder arrangement	In-Line																																					
Aspiration	Turbocharged after-water cooling																																					
Prime Rating Power (kW/kVA)	20kW/25kVA																																					
Standby Rating Power (kW/kVA)	22kW/27.5kVA																																					
Control Panel	Digital																																					
Speed governor	Electronic																																					
Cooling system	Water Cooling Cycle																																					
Phase	3																																					
Rpm	1800																																					
Volts	230Vac																																					
Frequency	60Hz																																					
Power Factor	0.8																																					
Fuel consumption at 100% load (L/H)	8.6L/H																																					
Fuel Tank Capacity	85L																																					
Insulation	Class H																																					
Starter motor	24V																																					
Exciter type	Single bearing, Brushless, Self-excited																																					
	<table><tr><td>KVA</td><td>SOUND LEVEL</td></tr><tr><td>25</td><td>75dBA@7m</td></tr><tr><td>50-250</td><td>80dBA@7m</td></tr><tr><td>500-750</td><td>90dBA@7m</td></tr></table>	KVA	SOUND LEVEL	25	75dBA@7m	50-250	80dBA@7m	500-750	90dBA@7m																													
KVA	SOUND LEVEL																																					
25	75dBA@7m																																					
50-250	80dBA@7m																																					
500-750	90dBA@7m																																					
	<p><b>ADDITIONAL TECHNICAL SPECIFICATIONS:</b></p> <p><b><u>Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices</u></b></p> <p>1. 230 volts, Single phase, Standby power mobile generator sets, silent type.</p>																																					

	<ol style="list-style-type: none"> <li>2. Built-in circuit breaker based on Molded-Case-Switch components.</li> <li>3. All Generator sets built with anti-vibration rubber pads.</li> </ol> <p><b>Supply, Delivery, Installation, Testing and Commissioning of <u>18 Units Prime Power Generator Set</u> for Port Management Offices</b></p> <ol style="list-style-type: none"> <li>1. 230 volts, 3 phase, Prime power generators sets, wall mounted/floor standing ATS, Synchronizer with NEMA enclosure equal to the capacity of the generator set.</li> <li>2. Transfer switched based on Molded-Case-Switch components.</li> <li>3. All Generator sets must come with anti-vibration rubber pads.</li> </ol>	
	<p><b>WARRANTY</b></p> <ol style="list-style-type: none"> <li>a) One (1) year warranty for manufacturing defects from the date of receipt of the Certificate of Acceptance.</li> <li>b) Two (2) years warranty for services from the date of receipt of the Certificate of Acceptance.</li> <li>c) The Supplier shall warrant the availability of spare parts for a period of at least five (5) years from the purchase of the subject units. Spare parts must be available in case of immediate repair within the warranty period.</li> <li>d) If equipment is inoperable and malfunctioning, the winning bidder shall provide maintenance service to the site within seventy two (72) hours after receipt of notification within warranty period.</li> </ol>	

## GENERAL REQUIREMENTS

### 1. Maintenance.

The supplier shall provide quarterly preventive maintenance service within 2-year warranty period.

### 2. Training/Seminar.

The Supplier must conduct a Generator Set Unit Orientation and Preventive Maintenance Seminar.

### 3. Provisions.

- a.) Complete set of standard tools for the Generator Sets, Operating and Parts Manual.
- b.) Initial diesel in tank for testing, upon delivery of Generator Sets.
- c.) Provision of anti-vibration rubber
- d.) Complete testing and commissioning of Generator Sets.

Item Description				
	PMO	Capacity (Prime Power)	Deployment	Major Component: 100% Copper High Amperage Cabling Requirements and other Accessories
1	Mindoro	500 KVA, 3 Phase (with Synchronizer)	Baseport, Port of Calapan	Free Standing ATS, Synchronizer and Floor Standing Air Circuit Breaker with NEMA Enclosure @2500A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @6840mtrs., Complete set of Copper Grounding, Pure copper terminal lugs long barrel and solderless connector
2	Negros Oriental/ Siquijor	150 KVA, 3 Phase	TMO Guihulngan	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		150 KVA, 3 Phase	Port of Lazi	Free Standing ATS and Wall Mounted Main

				Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector	
		150 KVA, 3 Phase	TMO Liloan	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector	
3	Eastern Leyte/ Samar	100 KVA, 3 Phase	Port of San Ricardo	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector	
		150 KVA, 3 Phase	TMO San Carlos	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector	
4	Negros Occ./ Bacolod/ Banago/ Bredco				
5	Bohol	750 KVA, 3 Phase	Baseport, Port of Tagbilaran	For Replacement of Generator Set Only	
		250 KVA, 3 Phase	TMO Jagna	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @500A 3P, 185mm <sup>2</sup> -570A High Amperage Copper Stranded @720mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector	
		125 KVA, 3 Phase	TMO Talibon	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @	

				300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		750 KVA, 3 Phase	TMO Tubigon	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @2000A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @2490mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		125 KVA, 3 Phase	TMO Getafe	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @ 300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		125 KVA, 3 Phase	TMO Loon	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @ 300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
	6	150 KVA, 3 Phase	Baseport, Port of Surigao	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		100 KVA, 3 Phase	TMO Siargao	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper

				terminal lug long barrel and solderless connector
	100 KVA, 3 Phase	TMO Lipata		Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
	50 KVA, 3 Phase	Port of Del Carmen		Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @125A 3P, 35mm <sup>2</sup> -195A High Amperage Copper Stranded @1260mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
	25KVA, 3 Phase	Port of Sta. Monica		Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @125A 3P, 25mm <sup>2</sup> -155A High Amperage Copper Stranded @660mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
TOTAL NO. OF UNITS			18	

**OTHER REQUIREMENTS:**

Copies of the following duly authenticated documents must be submitted as part of the technical proposal. **The original copies of these documents with Red Ribbon shall be submitted during bid opening in a separate envelope.**

**A. For Generator Manufacturer :**

- a.) Certificate of Manufacturer
- b.) Certificate of Product Origin
- c.) Certificate of Distributorship
- d.) Certificate of Factory Coupling 60 days fresh from Manufacturing
- e.) Standard Certificates - ISO9001:2015, ISO14001:2015 and CE Certificate of

	<p>Conformity that Generator Set passed EU or US Standard.</p> <p>f.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Engine</p> <p>g.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Controller</p> <p>h.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Alternator</p> <p>i.) Certificate of Availability of Authorized Service Center (in the Philippines)</p> <p><b>a. For High Amperage Cable Manufacturer:</b></p> <p>a.) Standard Certificates – ISO 9001:2015, ISO14001:2015 and ISO45001:2018</p>	
	<p><b>TESTING</b></p> <p>The equipment shall be tested (on/off and running for at least 10 minutes) after installation to the respective PMOs as per deployment list.</p>	
	<p>All other provisions stated in the Terms of Reference not included herein.</p>	

## TERMS OF REFERENCE

### SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF 43 UNITS GENERATOR SETS FOR PORT MANAGEMENT OFFICES (PMOs)

This Terms of Reference provides the technical description and other terms and conditions for the Supply, Delivery, Installation, Testing and Commissioning of Generator Sets for use of the Philippine Ports Authority Port Management Offices.

#### I. OBJECTIVES

The Philippine Ports Authority seeks to procure generator sets for the Port Management Offices (PMOs) to ensure uninterrupted operations and services throughout the ports and terminals.

#### II. SCOPE OF WORK

1. Supply and delivery of the brand new generator sets and Automatic Transfer Switch (ATS).
2. Mobilization of manpower, equipment and technical supervisions.
3. Installation of the equipment at the designated deployment ports.
4. Testing and commissioning of the equipment per port or terminal.

#### III. DEPLOYMENT

- A. LOT I: Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices

Generator Set Requirements				
	PMO	Capacity	Qty.	Deployment
1	NCR NORTH	50 KVA, Single Phase	1	Baseport
2	NCR SOUTH	50 KVA, Single Phase	1	Baseport
3	Bataan/Aurora	50 KVA, Single Phase	1	Baseport
4	Northern Luzon	50 KVA, Single Phase	1	Baseport
5	Batangas	50 KVA, Single Phase	1	Baseport
6	Bicol	50 KVA, Single Phase	1	Baseport
7	Palawan	50 KVA, Single Phase	1	Baseport
8	Mindoro	50 KVA, Single Phase	1	Baseport
9	Marinduque/ Quezon	50 KVA, Single Phase	1	Baseport
10	Masbate	50 KVA, Single Phase	1	Baseport
11	Negros Oriental/Siquijor	50 KVA, Single Phase	1	Baseport
12	Panay Guimaras	50 KVA, Single Phase	1	Baseport
13	Eastern Leyte/Samar	50 KVA, Single Phase	1	Baseport

14	Negros Occidental/ Bacolod/ Banago/ Bredco	50 KVA, Single Phase	1	Baseport
15	Western Leyte/Biliran	50 KVA, Single Phase	1	Baseport
16	Bohol	50 KVA, Single Phase	1	Baseport
17	Misamis Oriental/ Cagayan De Oro	50 KVA, Single Phase	1	Baseport
18	Lanao Del Norte/Iligan	50 KVA, Single Phase	1	Baseport
19	Misamis Occidental/Ozamis	50 KVA, Single Phase	1	Baseport
20	Surigao	50 KVA, Single Phase	1	Baseport
21	Agusan	50 KVA, Single Phase	1	Baseport
22	SOCSARGEN	50 KVA, Single Phase	1	Baseport
23	Davao	50 KVA, Single Phase	1	Baseport
24	Zamboanga	50 KVA, Single Phase	1	Baseport
25	Zamboanga Del Norte	50 KVA, Single Phase	1	Baseport
<b>TOTAL NO. OF UNITS</b>			<b>25</b>	

**B. LOT II: Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for Port Management Offices**

Generator Sets Requirements				
	PMO	Capacity	Qty.	Deployment
1	Mindoro	500 KVA, 3 Phase (with Synchronizer)	2	Baseport, Port of Calapan
2	Negros Oriental/Siquijor	150 KVA, 3 Phase	1	TMO Guihulngan
		150 KVA, 3 Phase	1	Port of Lazi
3	Eastern Leyte/ Samar	150 KVA, 3 Phase	1	TMO Liloan
		100 KVA, 3 Phase	1	Port of San Ricardo
4	Negros Occidental/ Bacolod/ Banago/ Bredco	150 KVA, 3 Phase	1	TMO San Carlos
5	Bohol	750 KVA, 3 Phase	1	Baseport, Port of Tagbilaran
		250 KVA, 3 Phase	1	TMO Jagna
		125 KVA, 3 Phase	1	TMO Talibon
		750 KVA, 3 Phase	1	TMO Tubigon
		125 KVA, 3 Phase	1	TMO Getafe
		125 KVA, 3 Phase	1	TMO Loon
6	Surigao	150 KVA, 3 Phase	1	Baseport, Port of Surigao
		100 KVA, 3 Phase	1	TMO Siargao
		100 KVA, 3 Phase	1	TMO Lipata
		50 KVA, 3 Phase	1	Port of Del Carmen
		25KVA, 3 Phase	1	Port of Sta. Monica
TOTAL NO. OF UNITS			18	

#### **IV. APPROVED BUDGET FOR THE CONTRACT**

The Approved Budget for the Contract is Four Hundred Twenty-Two Million Six Hundred Sixty-Seven Thousand One Hundred Twenty Pesos (P 422,667,120.00).

	<b>PROJECT</b>	
<b>LOT I</b>	Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices	<b>P 100,000,000.00</b>
<b>LOT II</b>	Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Sets for Port Management Offices	<b>P 322,667,120.00</b>
<b>TOTAL</b>		<b>P 422,667,120.00</b>

#### **V. A. TECHNICAL SPECIFICATIONS - GENERATOR SETS**

**LOT I: Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices**

##### **1. Technical Specification- Mobile Generator Set**

##### **50kVA Standby Power Mobile Generator Set**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	36.4kW/45.5kVA
Standby Rating Power (kW/kVA)	40kW/50kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	Single
Rpm	1800
Volts	230Vac
Frequency	60hZ

Power Factor	0.8
Fuel consumption at 100% load (L/H)	15.9L/H
Fuel Tank Capacity	160L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

## **2. Technical Specification- Trailer and Enclosure**

- a. Fork pockets
- b. Interior Cabinet and Control Panel Lightning
- c. 3-Point Contact, Deep ladder
- d. Stacked Access Doors with Auto Shutdown
- e. Large Service Doors
- f. All Aluminum Enclosure
- g. 110% Oil & Coolant Containment
- h. Rear Controller Access
- i. Easy-to-use controller
- j. Diamond Anti-Skid Plating
- k. LED Trailer Lighting

## **LOT II: Supply, Delivery, Installation, Testing and Commissioning of 18 Units Prime Power Generator Set for Ports Management Offices**

### **1. Two (2) Units 500KVA Prime Power Generator Set (with Synchronizer) Baseport Port of Calapan, PMO Mindoro**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	400kW/500kVA
Standby Rating Power (kW/kVA)	440kW/550kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle

Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	104.1L/H
Fuel Tank Capacity	850L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**2. One (1) Unit 150KVA Prime Power Generator Set  
Port of Guihulngan, PMO Negros Oriental/ Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ

Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**3. One (1) Unit 150KVA Prime Power Generator Set  
Port of Lazi, PMO Negros Oriental/ Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V

Exciter type	Single bearing, Brushless, Self-excited
--------------	---

**4. One (1) Unit 150KVA Prime Power Generator Set  
Port of Liloan, PMO Eastern Leyte/Samar**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**5. One (1) Unit 100KVA Prime Power Generator Set  
Port of San Ricardo, PMO Eastern Leyte/Samar**

Number of cylinders	4
---------------------	---

Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	80kW/100kVA
Standby Rating Power (kW/kVA)	88kW/110kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	28.5L/H
Fuel Tank Capacity	150L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**6. One (1) Unit 150KVA Prime Power Generator Set  
Port of San Carlos, PMO Negros Occidental**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	120kW/150kVA
Standby Rating Power (kW/kVA)	132kW/165kVA

Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60Hz
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**7. One (1) Unit 750KVA Prime Power Generator Set  
Baseport, Port of Tagbilaran, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	600kW/750kVA
Standby Rating Power (kW/kVA)	660kW/825kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800

Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	140L/H
Fuel Tank Capacity	1200L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**8. One (1) Unit 250KVA Prime Power Generator Set  
Port of Jagna, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	200kW/250kVA
Standby Rating Power (kW/kVA)	220kW/275kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	59L/H
Fuel Tank Capacity	350L

Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**9. One (1) Unit 125KVA Prime Power Generator Set  
Port of Talibon, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	100kW/125kVA
Standby Rating Power (kW/kVA)	110kW/137.5kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	29.7L/H
Fuel Tank Capacity	210L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**10. One (1) Unit 750KVA Prime Power Generator Set  
Port of Tubigon, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	600kW/750kVA
Standby Rating Power (kW/kVA)	660kW/825kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	140L/H
Fuel Tank Capacity	1200L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**11. One (1) Unit 125KVA Prime Power Generator Set  
Port of Getafe, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling

Prime Rating Power (kW/kVA)	100kW/125kVA
Standby Rating Power (kW/kVA)	110kW/137.5kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60Hz
Power Factor	0.8
Fuel consumption at 100% load (L/H)	29.7L/H
Fuel Tank Capacity	210L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**12. One (1) Unit 125KVA Prime Power Generator Set  
Port of Loon, PMO Bohol**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	100kW/125kVA
Standby Rating Power (kW/kVA)	110kW/137.5kVA
Control Panel	Digital
Speed governor	Electronic

<b>Cooling system</b>	<b>Water Cooling Cycle</b>
<b>Phase</b>	<b>3</b>
<b>Rpm</b>	<b>1800</b>
<b>Volts</b>	<b>230Vac</b>
<b>Frequency</b>	<b>60hZ</b>
<b>Power Factor</b>	<b>0.8</b>
<b>Fuel consumption at 100% load (L/H)</b>	<b>29.7L/H</b>
<b>Fuel Tank Capacity</b>	<b>210L</b>
<b>Insulation</b>	<b>Class H</b>
<b>Starter motor</b>	<b>24V</b>
<b>Exciter type</b>	<b>Single bearing, Brushless, Self-excited</b>

**13. One (1) Unit 150KVA Prime Power Generator Set  
Baseport Port of Surigao, PMO Surigao**

<b>Number of cylinders</b>	<b>6</b>
<b>Cylinder arrangement</b>	<b>In-Line</b>
<b>Aspiration</b>	<b>Turbocharged after-water cooling</b>
<b>Prime Rating Power (kW/kVA)</b>	<b>120kW/150kVA</b>
<b>Standby Rating Power (kW/kVA)</b>	<b>132kW/165kVA</b>
<b>Control Panel</b>	<b>Digital</b>
<b>Speed governor</b>	<b>Electronic</b>
<b>Cooling system</b>	<b>Water Cooling Cycle</b>
<b>Phase</b>	<b>3</b>
<b>Rpm</b>	<b>1800</b>
<b>Volts</b>	<b>230Vac</b>
<b>Frequency</b>	<b>60hZ</b>

Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**14. One (1) Unit 100KVA Prime Power Generator Set  
Port of Siargao, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	80kW/100kVA
Standby Rating Power (kW/kVA)	88kW/110kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	28.5L/H
Fuel Tank Capacity	150L
Insulation	Class H
Starter motor	24V

Exciter type	Single bearing, Brushless, Self-excited
--------------	---

**15. One (1) Unit 100KVA Prime Power Generator Set  
Port of Lipata, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	80kW/100kVA
Standby Rating Power (kW/kVA)	88kW/110kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	28.5L/H
Fuel Tank Capacity	150L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**16. One (1) Unit 50KVA Prime Power Generator Set  
Port of Del Carmen, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line

Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	40kW/50kVA
Standby Rating Power (kW/kVA)	44kW/55kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	15.9L/H
Fuel Tank Capacity	85L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**17. One (1) Unit 25KVA Prime Power Generator Set  
Port of Sta. Monica, PMO Surigao**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	20kW/25kVA
Standby Rating Power (kW/kVA)	22kW/27.5kVA
Control Panel	Digital

Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	8.6L/H
Fuel Tank Capacity	85L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

KVA	SOUND LEVEL
25	75dBA@7m
50-250	80dBA@7m
500-750	90dBA@7m

#### **V. B. TECHNICAL SPECIFICATIONS - GENERATOR SETS**

##### **LOT I: Supply, Delivery, Testing and Commissioning of 25 Units Standby Power Mobile Generator Sets with Trailer and Enclosure for Port Management Offices**

1. 230 volts, Single phase, Standby power mobile generator sets, silent type.
2. Built-in circuit breaker based on Molded-Case-Switch components.
3. All Generator sets built with anti-vibration rubber pads.

**LOT II: Supply, Delivery, Installation, Testing and Commissioning of 18 Units  
Prime Power Generator Set for Port Management Offices**

1. 230 volts, 3 phase, Prime power generators sets, wall mounted/floor standing ATS, Synchronizer with NEMA enclosure equal to the capacity of the generator set.
2. Transfer switched based on Molded-Case-Switch components.
3. All Generator sets must come with anti-vibration rubber pads.

**VI. DELIVERY**

The duration of the project shall be one hundred fifty (150) calendar days from receipt of Notice to Proceed subject to the following:

1. Delivery at warehouse within Metro Manila (for inspection of PPA Head Office representatives) within ninety (90) calendar days.
2. Delivery, installation, testing and commissioning at the PMOs within sixty (60) calendar days after inspection and acceptance by PPA Head Office representatives.

**VII. PAYMENT**

1. 70% of contract cost – After inspection and acceptance by PPA Head Office.
2. 30% of contract cost – After installation, testing, commissioning, inspection and acceptance by PMOs.

**VIII. WARRANTY**

1. One (1) year warranty for manufacturing defects from the date of receipt of the Certificate of Acceptance.
2. Two (2) years warranty for parts and services from the date of receipt of the Certificate of Acceptance.
3. The Supplier shall warrant the availability of spare parts for a period of at least five (5) years from the purchase of the subject units. Spare parts must be available in case of immediate repair within the warranty period.
4. If equipment is inoperable and malfunctioning, the winning bidder shall provide maintenance service to the site within seventy two (72) hours after receipt of notification within warranty period.

## IX. GENERAL REQUIREMENTS

1. Must have completed a single contract similar to the contract to be bid whose value must be at least equivalent to fifty percent (50%) of the ABC. For this purpose, a similar contract shall refer to the Supply, Delivery, Installation and Commissioning of Generator Sets.

### 2. Maintenance.

The supplier shall provide quarterly preventive maintenance service within 2-year warranty period.

### 3. Training/Seminar.

The Supplier must conduct a Generator Set Unit Orientation and Preventive Maintenance Seminar.

### 4. Provisions.

- a.) Complete set of standard tools for the Generator Sets, Operating and Parts Manual.
- b.) Initial diesel in tank for testing, upon delivery of Generator Sets.
- c.) Provision of anti-vibration rubber.
- d.) Complete testing and commissioning of Generator Sets.

Item Description				
	PMO	Capacity (Prime Power)	Deployment	Major Component: 100% Copper High Amperage Cabling Requirements and other Accessories
1	Mindoro	500 KVA, 3 Phase (with Synchronizer)	Baseport, Port of Calapan	Free Standing ATS, Synchronizer and Floor Standing Air Circuit Breaker with NEMA Enclosure @2500A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @6840mtrs., Complete set of Copper Grounding, Pure copper terminal lugs long barrel and solderless connector
2	Negros Oriental/Siquijor	150 KVA, 3 Phase	TMO Guihulngan	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		150 KVA, 3 Phase	Port of Lazi	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper

				grounding, pure copper terminal lug long barrel and solderless connector
3	Eastern Leyte/ Samar	150 KVA, 3 Phase	TMO Liloan	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		100 KVA, 3 Phase	Port of San Ricardo	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
4	Negros Occidental/ Bacolod/ Banago/ Bredco	150 KVA, 3 Phase	TMO San Carlos	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
5	Bohol	750 KVA, 3 Phase	Baseport, Port of Tagbilaran	For Replacement of Generator Set Only
		250 KVA, 3 Phase	TMO Jagna	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @500A 3P, 185mm <sup>2</sup> -570A High Amperage Copper Stranded @720mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		125 KVA, 3 Phase	TMO Talibon	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @ 300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		750 KVA, 3 Phase	TMO Tubigon	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @2000A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @2490mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		125 KVA, 3 Phase	TMO Getafe	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @ 300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper

				grounding, pure copper terminal lug long barrel and solderless connector
		125 KVA, 3 Phase	TMO Loon	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @ 300A 3P, 95mm <sup>2</sup> -370A High Amperage Copper Stranded @1080mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
6	Surigao	150 KVA, 3 Phase	Baseport, Port of Surigao	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @400A 3P, 120mm <sup>2</sup> -430A High Amperage Copper Stranded @1000mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		100 KVA, 3 Phase	TMO Siargao	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		100 KVA, 3 Phase	TMO Lipata	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @250A 3P, 70mm <sup>2</sup> -295A High Amperage Copper Stranded @1120mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		50 KVA, 3 Phase	Port of Del Carmen	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @125A 3P, 35mm <sup>2</sup> -195A High Amperage Copper Stranded @1260mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		25KVA, 3 Phase	Port of Sta. Monica	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @125A 3P, 25mm <sup>2</sup> -155A High Amperage Copper Stranded @660mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
TOTAL NO. OF UNITS			18	

## **X. OTHER REQUIREMENTS**

Copies of the following duly authenticated documents must be submitted as part of the technical proposal. **The original copies of these documents with Red Ribbon shall be submitted during bid opening in a separate envelope.**

### **a. For Generator Manufacturer :**

- a.) Certificate of Manufacturer
- b.) Certificate of Product Origin
- c.) Certificate of Distributorship
- d.) Certificate of Factory Coupling 60 days fresh from Manufacturing
- e.) Standard Certificates – ISO9001:2015, ISO14001:2015 and CE Certificate of Conformity that Generator Set passed EU or US Standard.
- f.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Engine
- g.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Controller
- h.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Alternator
- i.) Certificate of Availability of Authorized Service Center (in the Philippines)

### **b. For High Amperage Cable Manufacturer:**

- a.) Standard Certificates – ISO9001:2015 , ISO14001:2015 and ISO45001:2018

## **XI. TESTING**

The equipment shall be tested (on/off and running for at least 10 minutes) after installation to the respective PMOs as per deployment list.

  
**ERIC E. DIMACULANGAN**  
Acting Manager  
Administrative Services Department

## ***Section VIII. Checklist of Technical and Financial Documents***

# Checklist of Technical and Financial Documents

## I. TECHNICAL COMPONENT ENVELOPE

### *Class "A" Documents*

#### Legal Documents

- ☐ (a) Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages) in accordance with Section 8.5.2 of the IRR;

#### Technical Documents

- ☐ (b) Statement of the prospective bidder of all its ongoing government and private contracts, including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; **and**
- ☐ (c) Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid, except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within the relevant period as provided in the Bidding Documents; **and**
- ☐ (d) Original copy of Bid Security. If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission;

**Or**

Original copy of Notarized Bid Securing Declaration; **and**

- ☐ (e) Conformity with the Technical Specifications, which may include production/delivery schedule, manpower requirements, and/or after-sales/parts, if applicable; **and**
- ☐ (f) Original duly signed Omnibus Sworn Statement (OSS); **and** if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

#### Financial Documents

- ☐ (g) The prospective bidder's computation of Net Financial Contracting Capacity (NFCC);  
**or**  
A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

***Class "B" Documents***

- ☐ (h) If applicable, a duly signed joint venture agreement (JVA) in case the joint venture is already in existence;  
**or**

duly notarized statements from all the potential joint venture partners stating the following:

- a. that they will enter into and abide by the provisions of the JVA in the instance that the bid is successful; and
- b. failure to enter into JVA in the event of a contract award shall be a ground for bid disqualification and subsequent forfeiture of the bid security.

***Other documentary requirements under RA No. 9184 (as applicable)***

- ☐ (i) *[For foreign bidders claiming by reason of their country's extension of reciprocal rights to Filipinos]* Certification from the relevant government office of their country stating that Filipinos are allowed to participate in government procurement activities for the same item or product.
- ☐ (j) Certification from the DTI if the Bidder claims preference as a Domestic Bidder or Domestic Entity.

**II. FINANCIAL COMPONENT ENVELOPE**

- ☐ (a) Original of duly signed and accomplished Financial Bid Form; **and**
- ☐ (b) Original of duly signed and accomplished Price Schedule(s).

**Bid Form for the Procurement of Goods**  
**[shall be submitted with the Bid]**

---

**BID FORM**

Date : \_\_\_\_\_

Project Identification No. : \_\_\_\_\_

To: [name and address of Procuring Entity]

Having examined the Philippine Bidding Documents (PBDs) including the Supplemental or Bid Bulletin Numbers [insert numbers], the receipt of which is hereby duly acknowledged, we, the undersigned, offer to [supply/deliver/perform] [description of the Goods] in conformity with the said PBDs for the sum of [total Bid amount in words and figures] or the total calculated bid price, as evaluated and corrected for computational errors, and other bid modifications in accordance with the Price Schedules attached herewith and made part of this Bid. The total bid price includes the cost of all taxes, such as, but not limited to: [specify the applicable taxes, e.g. (i) value added tax (VAT), (ii) income tax, (iii) local taxes, and (iv) other fiscal levies and duties], which are itemized herein or in the Price Schedules,

If our Bid is accepted, we undertake:

- a. to deliver the goods in accordance with the delivery schedule specified in the Schedule of Requirements of the Philippine Bidding Documents (PBDs);
- b. to provide a performance security in the form, amounts, and within the times prescribed in the PBDs;
- c. to abide by the Bid Validity Period specified in the PBDs and it shall remain binding upon us at any time before the expiration of that period.

Until a formal Contract is prepared and executed, this Bid, together with your written acceptance thereof and your Notice of Award, shall be binding upon us.

We understand that you are not bound to accept the Lowest Calculated Bid or any Bid you may receive.

We certify/confirm that we comply with the eligibility requirements pursuant to the PBDs.

The undersigned is authorized to submit the bid on behalf of [name of the bidder] as evidenced by the attached [state the written authority].

We acknowledge that failure to sign each and every page of this Bid Form, including the attached Schedule of Prices, shall be a ground for the rejection of our bid.

Name: \_\_\_\_\_

Legal capacity: \_\_\_\_\_

Signature: \_\_\_\_\_  
Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_  
Date: \_\_\_\_\_

Name of Bidder \_\_\_\_\_ Project ID No. \_\_\_\_\_ Page \_\_\_\_ of \_\_\_\_

Name: \_\_\_\_\_

Signature: \_\_\_\_\_

56

**Price Schedule for Goods Offered from Within the Philippines**  
**[shall be submitted with the Bid if bidder is offering goods from within the Philippines]**

---

**For Goods Offered from Within the Philippines**

Name of Bidder \_\_\_\_\_ Project ID No. \_\_\_\_\_ Page \_\_\_\_ of \_\_\_\_

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transportation and all other costs incidental to delivery, per item	Sales and other taxes payable if Contract is awarded, per item	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination (col 9) x (col 4)

Name: \_\_\_\_\_

Legal Capacity: \_\_\_\_\_

Signature: \_\_\_\_\_

Duly authorized to sign the Bid for and behalf of: \_\_\_\_\_

**Bid Securing Declaration Form**  
[shall be submitted with the Bid if bidder opts to provide this form of bid security]

REPUBLIC OF THE PHILIPPINES)  
CITY OF \_\_\_\_\_) S.S.

**BID SECURING DECLARATION**  
Project Identification No.: [Insert number]

To: [Insert name and address of the Procuring Entity]

I/We, the undersigned, declare that:

1. I/We understand that, according to your conditions, bids must be supported by a Bid Security, which may be in the form of a Bid Securing Declaration.
2. I/We accept that: (a) I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of two (2) years upon receipt of your Blacklisting Order; and, (b) I/we will pay the applicable fine provided under Section 6 of the Guidelines on the Use of Bid Securing Declaration, within fifteen (15) days from receipt of the written demand by the procuring entity for the commission of acts resulting to the enforcement of the bid securing declaration under Sections 23.1(b), 34.2, 40.1 and 69.1, except 69.1(f), of the IRR of RA No. 9184; without prejudice to other legal action the government may undertake.
3. I/We understand that this Bid Securing Declaration shall cease to be valid on the following circumstances:
  - a. Upon expiration of the bid validity period, or any extension thereof pursuant to your request;
  - b. I am/we are declared ineligible or post-disqualified upon receipt of your notice to such effect, and (i) I/we failed to timely file a request for reconsideration or (ii) I/we filed a waiver to avail of said right; and
  - c. I am/we are declared the bidder with the Lowest Calculated Responsive Bid, and I/we have furnished the performance security and signed the Contract.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this \_\_\_\_ day of [month]  
[year] at [place of execution].

[Insert NAME OF BIDDER OR ITS  
AUTHORIZED REPRESENTATIVE]  
[Insert signatory's legal capacity]  
Affiant

[Jurat]  
[Format shall be based on the latest Rules on Notarial Practice]

Contract Agreement Form for the Procurement of Goods (Revised)  
[Not required to be submitted with the Bid, but it shall be submitted within ten (10) days after  
receiving the Notice of Award]

---

**CONTRACT AGREEMENT**

THIS AGREEMENT made the \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_ between [name of  
PROCURING ENTITY] of the Philippines (hereinafter called “the Entity”) of the one part and  
[name of Supplier] of [city and country of Supplier] (hereinafter called “the Supplier”) of the  
other part;

WHEREAS, the Entity invited Bids for certain goods and ancillary services,  
particularly [brief description of goods and services] and has accepted a Bid by the Supplier  
for the supply of those goods and services in the sum of [contract price in words and figures in  
specified currency] (hereinafter called “the Contract Price”).

**NOW THIS AGREEMENT WITNESSETH AS FOLLOWS:**

1. In this Agreement words and expressions shall have the same meanings as are  
respectively assigned to them in the Conditions of Contract referred to.
2. The following documents as required by the 2016 revised Implementing Rules and  
Regulations of Republic Act No. 9184 shall be deemed to form and be read and  
construed as integral part of this Agreement, viz.:
  - i. Philippine Bidding Documents (PBDs);
    - i. Schedule of Requirements;
    - ii. Technical Specifications;
    - iii. General and Special Conditions of Contract; and
    - iv. Supplemental or Bid Bulletins, if any
  - ii. Winning bidder’s bid, including the Eligibility requirements, Technical and  
Financial Proposals, and all other documents or statements submitted;  
  
Bid form, including all the documents/statements contained in the Bidder’s  
bidding envelopes, as annexes, and all other documents submitted (e.g.,  
Bidder’s response to request for clarifications on the bid), including  
corrections to the bid, if any, resulting from the Procuring Entity’s bid  
evaluation;
  - iii. Performance Security;
  - iv. Notice of Award of Contract; and the Bidder’s conforme thereto; and
  - v. Other contract documents that may be required by existing laws and/or the  
Procuring Entity concerned in the PBDs. Winning bidder agrees that  
additional contract documents or information prescribed by the GPPB that  
are subsequently required for submission after the contract execution, such

as the Notice to Proceed, Variation Orders, and Warranty Security, shall likewise form part of the Contract.

3. In consideration for the sum of [total contract price in words and figures] or such other sums as may be ascertained, [Named of the bidder] agrees to [state the object of the contract] in accordance with his/her/its Bid.
4. The [Name of the procuring entity] agrees to pay the above-mentioned sum in accordance with the terms of the Bidding.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of the Republic of the Philippines on the day and year first above written.

[Insert Name and Signature]

[Insert Name and Signature]

[Insert Signatory's Legal Capacity]

[Insert Signatory's Legal Capacity]

for:

for:

[Insert Procuring Entity]

[Insert Name of Supplier]

#### Acknowledgment

[Format shall be based on the latest Rules on Notarial Practice]

Omnibus Sworn Statement (Revised)  
[shall be submitted with the Bid]

---

REPUBLIC OF THE PHILIPPINES )  
CITY/MUNICIPALITY OF \_\_\_\_\_ ) S.S.

AFFIDAVIT

I, [Name of Affiant], of legal age, [Civil Status], [Nationality], and residing at [Address of Affiant], after having been duly sworn in accordance with law, do hereby depose and state that:

1. [Select one, delete the other:]

[If a sole proprietorship:] I am the sole proprietor or authorized representative of [Name of Bidder] with office address at [address of Bidder];

[If a partnership, corporation, cooperative, or joint venture:] I am the duly authorized and designated representative of [Name of Bidder] with office address at [address of Bidder];

2. [Select one, delete the other:]

[If a sole proprietorship:] As the owner and sole proprietor, or authorized representative of [Name of Bidder], I have full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached duly notarized Special Power of Attorney;

[If a partnership, corporation, cooperative, or joint venture:] I am granted full power and authority to do, execute and perform any and all acts necessary to participate, submit the bid, and to sign and execute the ensuing contract for [Name of the Project] of the [Name of the Procuring Entity], as shown in the attached [state title of attached document showing proof of authorization (e.g., duly notarized Secretary's Certificate, Board/Partnership Resolution, or Special Power of Attorney, whichever is applicable)];

3. [Name of Bidder] is not "blacklisted" or barred from bidding by the Government of the Philippines or any of its agencies, offices, corporations, or Local Government Units, foreign government/foreign or international financing institution whose blacklisting rules have been recognized by the Government Procurement Policy Board, by itself or by relation, membership, association, affiliation, or controlling interest with another blacklisted person or entity as defined and provided for in the Uniform Guidelines on Blacklisting;
4. Each of the documents submitted in satisfaction of the bidding requirements is an authentic copy of the original, complete, and all statements and information provided therein are true and correct;

5. [Name of Bidder] is authorizing the Head of the Procuring Entity or its duly authorized representative(s) to verify all the documents submitted;
6. [Select one, delete the rest:]

[If a sole proprietorship:] The owner or sole proprietor is not related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a partnership or cooperative:] None of the officers and members of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

[If a corporation or joint venture:] None of the officers, directors, and controlling stockholders of [Name of Bidder] is related to the Head of the Procuring Entity, members of the Bids and Awards Committee (BAC), the Technical Working Group, and the BAC Secretariat, the head of the Project Management Office or the end-user unit, and the project consultants by consanguinity or affinity up to the third civil degree;

7. [Name of Bidder] complies with existing labor laws and standards; and
8. [Name of Bidder] is aware of and has undertaken the responsibilities as a Bidder in compliance with the Philippine Bidding Documents, which includes:
  - a. Carefully examining all of the Bidding Documents;
  - b. Acknowledging all conditions, local or otherwise, affecting the implementation of the Contract;
  - c. Making an estimate of the facilities available and needed for the contract to be bid, if any; and
  - d. Inquiring or securing Supplemental/Bid Bulletin(s) issued for the [Name of the Project].
9. [Name of Bidder] did not give or pay directly or indirectly, any commission, amount, fee, or any form of consideration, pecuniary or otherwise, to any person or official, personnel or representative of the government in relation to any procurement project or activity.
10. In case advance payment was made or given, failure to perform or deliver any of the obligations and undertakings in the contract shall be sufficient grounds to constitute criminal liability for Swindling (Estafa) or the commission of fraud with unfaithfulness or abuse of confidence through misappropriating or converting any payment received by a person or entity under an obligation involving the duty to

deliver certain goods or services, to the prejudice of the public and the government of the Philippines pursuant to Article 315 of Act No. 3815 s. 1930, as amended, or the Revised Penal Code.

IN WITNESS WHEREOF, I have hereunto set my hand this \_\_\_ day of \_\_\_, 20\_\_\_ at \_\_\_\_\_, Philippines.

[Insert NAME OF BIDDER OR ITS  
AUTHORIZED REPRESENTATIVE]

[Insert signatory's legal capacity]

Affiant

[Jurat]

[Format shall be based on the latest Rules on Notarial Practice]

Performance Securing Declaration (Revised)

[if used as an alternative performance security but it is not required to be submitted with the Bid, as it shall be submitted within ten (10) days after receiving the Notice of Award]

---

REPUBLIC OF THE PHILIPPINES)  
CITY OF \_\_\_\_\_ ) S.S.

PERFORMANCE SECURING DECLARATION

Invitation to Bid: [Insert Reference Number indicated in the Bidding Documents]

To: [Insert name and address of the Procuring Entity]

I/We, the undersigned, declare that:

1. I/We understand that, according to your conditions, to guarantee the faithful performance by the supplier/distributor/manufacture/contractor/consultant of its obligations under the Contract, I/we shall submit a Performance Securing Declaration within a maximum period of ten (10) calendar days from the receipt of the Notice of Award prior to the signing of the Contract.
2. I/We accept that: I/we will be automatically disqualified from bidding for any procurement contract with any procuring entity for a period of one (1) year for the first offense, or two (2) years for the second offense, upon receipt of your Blacklisting Order if I/We have violated my/our obligations under the Contract;
3. I/We understand that this Performance Securing Declaration shall cease to be valid upon:
  - a. issuance by the Procuring Entity of the Certificate of Final Acceptance, subject to the following conditions:
    - i. Procuring Entity has no claims filed against the contract awardee;
    - ii. It has no claims for labor and materials filed against the contractor; and
    - iii. Other terms of the contract; or
  - b. replacement by the winning bidder of the submitted PSD with a performance security in any of the prescribed forms under Section 39.2 of the 2016 revised IRR of RA No. 9184 as required by the end-user.

IN WITNESS WHEREOF, I/We have hereunto set my/our hand/s this \_\_\_\_ day of [month] [year] at [place of execution].

[Insert NAME OF BIDDER OR ITS  
AUTHORIZED REPRESENTATIVE]  
[Insert signatory's legal capacity]  
Affiant

[Jurat]  
[Format shall be based on the latest Rules on Notarial Practice]

**NET FINANCIAL CONTRACTING CAPACITY (NFCC)  
COMPUTATION**

- A. The values of the bidder's current assets and current liabilities shall be based on the data submitted to the BIR, through its Electronic Filing and Payment System (EFPS).

		Year 20
1.	Total Assets	
2.	Current Assets	
3.	Total Liabilities	
4.	Current Liabilities	
5.	Net Worth (1-3)	
6.	Net Working Capital (2-4)	

- B. The Net Financial Contracting Capacity (NFCC) based on the above data is computed as follows:

NFCC = [(Current asset minus current liabilities) (15)] minus the value of all outstanding or uncompleted portions of the projects under ongoing contracts, including awarded contracts yet to be started, coinciding with the contract to be bid

NFCC = Php \_\_\_\_\_

K = 15

Herewith attached are certified true copies of the income tax return and audited financial statement: stamped "RECEIVED" by the BIR or BIR authorized collecting agent for the immediately preceding year.

Submitted by:

\_\_\_\_\_  
Name of Supplier/Distributor/Manufacturer

\_\_\_\_\_  
Signature of Authorized Representative

**STATEMENT OF THE BIDDER'S ONGOING GOVERNMENT AND PRIVATE CONTRACTS,  
INCLUDING CONTRACTS AWARDED BUT NOT YET STARTED**

This is to certify that \_\_\_\_\_ has the following ongoing government and private contracts, including contracts awarded but not yet started:

NAME OF THE CONTRACT	DATE OF THE CONTRACT	CONTRACT DURATION	OWNER'S NAME & ADDRESS	KINDS OF GOODS/SERVICES DELIVERED	AMOUNT OF CONTRACT	VALUE OF OUTSTANDING CONTRACT	DATE OF DELIVERY

**\*PROOF OF CONTRACT TO BE PRESENTED AT POST-QUALIFICATION.**

\_\_\_\_\_  
Name and Signature of Authorized Representative

\_\_\_\_\_  
Date

**STATEMENT OF THE BIDDER'S SINGLE LARGEST COMPLETED CONTRACT (SLCC)  
SIMILAR TO THE CONTRACT TO BE BID**

This is to certify that \_\_\_\_\_ has completed the following:

NAME OF THE CONTRACT	DATE OF THE CONTRACT	CONTRACT DURATION	OWNER'S NAME & ADDRESS	KINDS OF GOODS	AMOUNT OF COMPLETED CONTRACT/S	DATE OF DELIVERY	END USER'S ACCEPTANCE OR OFFICIAL RECEIPT(S) OR SALES INVOICE ISSUED FOR THE CONTRACT*

\*TO BE ATTACHED TO THE STATEMENT

\_\_\_\_\_  
Name and Signature of Authorized Representative

\_\_\_\_\_  
Date