

**PHILIPPINE
PORTS
AUTHORITY**



SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF GENERATOR SETS (PHASE II)

**BID DOCUMENTS
BAC-PGCS-028-2020**

Table of Contents

Glossary of Acronyms, Terms, and Abbreviations.....	3
Section I. Invitation to Bid.....	6
Section II. Instructions to Bidders.....	9
1. Scope of Bid.....	10
2. Funding Information.....	10
3. Bidding Requirements.....	10
4. Corrupt, Fraudulent, Collusive, and Coercive Practices.....	10
5. Eligible Bidders.....	10
6. Origin of Goods.....	11
7. Subcontracts.....	11
8. Pre-Bid Conference.....	11
9. Clarification and Amendment of Bidding Documents.....	11
10. Documents comprising the Bid: Eligibility and Technical Components.....	11
11. Documents comprising the Bid: Financial Component.....	12
12. Bid Prices.....	12
13. Bid and Payment Currencies.....	13
14. Bid Security.....	13
15. Sealing and Marking of Bids.....	13
16. Deadline for Submission of Bids.....	13
17. Opening and Preliminary Examination of Bids.....	14
18. Domestic Preference.....	14
19. Detailed Evaluation and Comparison of Bids.....	14
20. Post-Qualification.....	15
21. Signing of the Contract.....	15
Section III. Bid Data Sheet.....	16
Section IV. General Conditions of Contract.....	18
1. Scope of Contract.....	19
2. Advance Payment and Terms of Payment.....	19
3. Performance Security.....	19
4. Inspection and Tests.....	19
5. Warranty.....	20
6. Liability of the Supplier.....	20
Section V. Special Conditions of Contract.....	21
Section VI. Schedule of Requirements.....	28
Section VII. Technical Specifications.....	29
Section VIII. Checklist of Technical and Financial Documents.....	84
Section IX. Bidding Forms	87

Glossary of Acronyms, Terms, and Abbreviations

ABC – Approved Budget for the Contract.

BAC – Bids and Awards Committee.

Bid – A signed offer or proposal to undertake a contract submitted by a bidder in response to and in consonance with the requirements of the bidding documents. Also referred to as *Proposal* and *Tender*. (2016 revised IRR, Section 5[c])

Bidder – Refers to a contractor, manufacturer, supplier, distributor and/or consultant who submits a bid in response to the requirements of the Bidding Documents. (2016 revised IRR, Section 5[d])

Bidding Documents – The documents issued by the Procuring Entity as the bases for bids, furnishing all information necessary for a prospective bidder to prepare a bid for the Goods, Infrastructure Projects, and/or Consulting Services required by the Procuring Entity. (2016 revised IRR, Section 5[e])

BIR – Bureau of Internal Revenue.

BSP – Bangko Sentral ng Pilipinas.

Consulting Services – Refer to services for Infrastructure Projects and other types of projects or activities of the GOP requiring adequate external technical and professional expertise that are beyond the capability and/or capacity of the GOP to undertake such as, but not limited to: (i) advisory and review services; (ii) pre-investment or feasibility studies; (iii) design; (iv) construction supervision; (v) management and related services; and (vi) other technical services or special studies. (2016 revised IRR, Section 5[i])

CDA - Cooperative Development Authority.

Contract – Refers to the agreement entered into between the Procuring Entity and the Supplier or Manufacturer or Distributor or Service Provider for procurement of Goods and Services; Contractor for Procurement of Infrastructure Projects; or Consultant or Consulting Firm for Procurement of Consulting Services; as the case may be, as recorded in the Contract Form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.

CIF – Cost Insurance and Freight.

CIP – Carriage and Insurance Paid.

CPI – Consumer Price Index.

DDP – Refers to the quoted price of the Goods, which means “delivered duty paid.”

DTI – Department of Trade and Industry.

EXW – Ex works.

FCA – “Free Carrier” shipping point.

FOB – “Free on Board” shipping point.

Foreign-funded Procurement or Foreign-Assisted Project– Refers to procurement whose funding source is from a foreign government, foreign or international financing institution as specified in the Treaty or International or Executive Agreement. (2016 revised IRR, Section 5[b]).

Framework Agreement – Refers to a written agreement between a procuring entity and a supplier or service provider that identifies the terms and conditions, under which specific purchases, otherwise known as “Call-Offs,” are made for the duration of the agreement. It is in the nature of an option contract between the procuring entity and the bidder(s) granting the procuring entity the option to either place an order for any of the goods or services identified in the Framework Agreement List or not buy at all, within a minimum period of one (1) year to a maximum period of three (3) years. (GPPB Resolution No. 27-2019)

GFI – Government Financial Institution.

GOCC – Government-owned and/or –controlled corporation.

Goods – Refer to all items, supplies, materials and general support services, except Consulting Services and Infrastructure Projects, which may be needed in the transaction of public businesses or in the pursuit of any government undertaking, project or activity, whether in the nature of equipment, furniture, stationery, materials for construction, or personal property of any kind, including non-personal or contractual services such as the repair and maintenance of equipment and furniture, as well as trucking, hauling, janitorial, security, and related or analogous services, as well as procurement of materials and supplies provided by the Procuring Entity for such services. The term “related” or “analogous services” shall include, but is not limited to, lease or purchase of office space, media advertisements, health maintenance services, and other services essential to the operation of the Procuring Entity. (2016 revised IRR, Section 5[r])

GOP – Government of the Philippines.

GPPB – Government Procurement Policy Board.

INCOTERMS – International Commercial Terms.

Infrastructure Projects – Include the construction, improvement, rehabilitation, demolition, repair, restoration or maintenance of roads and bridges, railways, airports, seaports, communication facilities, civil works components of information technology projects, irrigation, flood control and drainage, water supply, sanitation, sewerage and solid waste management systems, shore protection, energy/power and electrification facilities, national buildings, school buildings, hospital buildings, and other related construction projects of the government. Also referred to as *civil works or works*. (2016 revised IRR, Section 5[u])

LGUs – Local Government Units.

NFCC – Net Financial Contracting Capacity.

NGA – National Government Agency.

PhilGEPS - Philippine Government Electronic Procurement System.

Procurement Project – refers to a specific or identified procurement covering goods, infrastructure project or consulting services. A Procurement Project shall be described, detailed, and scheduled in the Project Procurement Management Plan prepared by the agency which shall be consolidated in the procuring entity's Annual Procurement Plan. (GPPB Circular No. 06-2019 dated 17 July 2019)

PSA – Philippine Statistics Authority.

SEC – Securities and Exchange Commission.

SLCC – Single Largest Completed Contract.

Supplier – refers to a citizen, or any corporate body or commercial company duly organized and registered under the laws where it is established, habitually established in business and engaged in the manufacture or sale of the merchandise or performance of the general services covered by his bid. (Item 3.8 of GPPB Resolution No. 13-2019, dated 23 May 2019). Supplier as used in these Bidding Documents may likewise refer to a distributor, manufacturer, contractor, or consultant.

UN – United Nations.



INVITATION TO BID

FOR THE SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF GENERATOR SETS (PHASE II)

The Philippine Ports Authority, through the Corporate Budget of the Authority for CY 2020, intends to apply the sum of **P450,000,000.00** being the Approved Budget for the Contract (ABC) to payments under the contract for the Supply, Delivery, Installation, Testing and Commissioning of Generator Sets (Phase II) (BAC PGCS-028-2020). Bids received in excess of the ABC shall be automatically rejected at bid opening.

The Philippine Ports Authority now invites bids for the above Procurement Project. Completion of the services shall be within Ninety (90) calendar days from the receipt by the successful bidder of the Notice to Proceed (delivery at warehouse within Metro Manila (for inspection of PPA head Office representatives) and within Sixty (60) calendar days after inspection and acceptance by PPA Head Office representatives, delivery, installation, testing and commissioning at the PMOs. Bidders should have completed, within five (5) years from the date of submission and receipt of bids, a contract similar to the Project. The description of an eligible bidder is contained in the Bidding Documents, particularly, in Section II (Instructions to Bidders).

Bidding will be conducted through open competitive bidding procedures using a non-discretionary "pass/fail" criterion as specified in the 2016 revised Implementing Rules and Regulations (IRR) of Republic Act (RA) 9184. Bidding is restricted to Filipino citizens/sole proprietorships, partnerships, or organizations with at least sixty percent (60%) interest or outstanding capital stock belonging to citizens of the Philippines, and to citizens or organizations of a country the laws or regulations of which grant similar rights or privileges to Filipino citizens, pursuant to RA 5183.

Prospective Bidders may obtain further information from the Philippine Ports Authority Bids and Awards Committee (BAC) and inspect the Bidding Documents at the address given below during 8:00 a.m. to 5:00 p.m., Monday to Friday.

A complete set of Bidding Documents may be acquired by interested Bidders on **23 November 2020** from the given address and website(s) below and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of **Fifty Thousand (P50,000.00) Pesos**. The Procuring Entity shall allow the bidder to present its proof of payment for the fees in person.

The Philippine Ports Authority's Bids and Awards Committee will hold a Pre-Bid Conference on **04 December 2020 at 10:00 a.m.** at the PPA Function Room, 7th Floor, PPA Bldg., Bonifacio Drive, South Harbor, Port Area, Manila, and/or through video conferencing or webcasting via zoom, which shall be open to all prospective bidders.

Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before **17 December 2020 at 9:00 a.m.** Late bids shall not be accepted.

All Bids must be accompanied by a bid security in any of the acceptable forms and in the amount stated in ITB Clause 14.

Bid opening shall be on **17 December 2020 at 10:00 a.m.** at the 7th Floor, PPA Building, A. Bonifacio Drive, South Harbor, Port Area, Manila. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.


The Philippine Ports Authority reserves the right to reject any and all bids, declare a failure of bidding, or not award the contract at any time prior to contract award in accordance with Sections 35.6 and 41 of the 2016 revised IRR of RA No. 9184, without thereby incurring any liability to the affected bidder or bidders.

For further information, please refer to:

BAC Secretariat, Philippine Ports Authority
5th Floor, PPA Bldg., A. Bonifacio Drive,
South Harbor, Port Area, Manila
Telephone Nos. 527-47-35

527-83-56 to 83 loc. 539

PPA Website: www.ppa.com.ph
GPPB Website: www.gppb.com.ph



MARK JONES PALOMAR
Chairperson, PPA Head Office Bids and Awards
Committee for the Procurement of Goods and
Consultancy Services (HO-BAC-PGCS)

Section II. Instructions to Bidders

1. Scope of Bid

The Procuring Entity, PHILIPPINE PORTS AUTHORITY wishes to receive Bids for the **Supply, Delivery, Installation, Testing and Commissioning of Generator Sets (Phase II)**, with identification number **BAC-PGCS-028-2020**.

The Procurement Project (referred to herein as “Project”) is composed of a single lot, the details of which are described in Section VII (Technical Specifications).

2. Funding Information

- 2.1. The Philippine Ports Authority through its corporate budget for the Calendar Year (CY) 2020 in the amount of **FOUR HUNDRED FIFTY MILLION PESOS (Php450,000,000.00)**.
- 2.2. The source of funding is the Corporate Budget of the PHILIPPINE PORTS AUTHORITY.

3. Bidding Requirements

The Bidding for the Project shall be governed by all the provisions of RA No. 9184 and its 2016 revised IRR, including its Generic Procurement Manuals and associated policies, rules and regulations as the primary source thereof, while the herein clauses shall serve as the secondary source thereof.

Any amendments made to the IRR and other GPPB issuances shall be applicable only to the ongoing posting, advertisement, or **IB** by the BAC through the issuance of a supplemental or bid bulletin.

The Bidder, by the act of submitting its Bid, shall be deemed to have verified and accepted the general requirements of this Project, including other factors that may affect the cost, duration and execution or implementation of the contract, project, or work and examine all instructions, forms, terms, and project requirements in the Bidding Documents.

4. Corrupt, Fraudulent, Collusive, and Coercive Practices

The Procuring Entity, as well as the Bidders and Suppliers, shall observe the highest standard of ethics during the procurement and execution of the contract. They or through an agent shall not engage in corrupt, fraudulent, collusive, coercive, and obstructive practices defined under Annex “I” of the 2016 revised IRR of RA No. 9184 or other integrity violations in competing for the Project.

5. Eligible Bidders

- 5.1. Only Bids of Bidders found to be legally, technically, and financially capable will be evaluated.
- 5.2. Foreign ownership limited to those allowed under the rules may participate in this Project.

- 5.3. Pursuant to Section 23.4.1.3 of the 2016 revised IRR of RA No.9184, the Bidder shall have an SLCC that is at least one (1) contract similar to the Project the value of which, adjusted to current prices using the PSA's CPI, must be at least equivalent to at least fifty percent (50%) of the ABC.
- 5.4. The Bidders shall comply with the eligibility criteria under Section 23.4.1 of the 2016 IRR of RA No. 9184.

6. Origin of Goods

There is no restriction on the origin of goods other than those prohibited by a decision of the UN Security Council taken under Chapter VII of the Charter of the UN, subject to Domestic Preference requirements under **ITB** Clause 18.

7. Subcontracts

- 7.1 The Bidder may subcontract portions of the Project to the extent allowed by the Procuring Entity as stated herein, but in no case more than twenty percent (20%) of the Project.

The Procuring Entity has prescribed that:

Subcontracting is not allowed.

8. Pre-Bid Conference

The Procuring Entity will hold a pre-bid conference for this Project on the specified date and time and either at its physical address at the PPA Function Room, 7th Floor, PPA Building, Bonifacio Drive, South Harbor, Port Area, Manila and/or through videoconferencing/webcasting as indicated in paragraph 6 of the **IB**.

9. Clarification and Amendment of Bidding Documents

Prospective bidders may request for clarification on and/or interpretation of any part of the Bidding Documents. Such requests must be in writing and received by the Procuring Entity, either at its given address or through electronic mail indicated in the **IB**, at least ten (10) calendar days before the deadline set for the submission and receipt of Bids.

10. Documents comprising the Bid: Eligibility and Technical Components

- 10.1. The first envelope shall contain the eligibility and technical documents of the Bid as specified in **Section VIII (Checklist of Technical and Financial Documents)**.
- 10.2. The Bidder's SLCC as indicated in **ITB** Clause 5.3 should have been completed within five (5) years prior to the deadline for the submission and receipt of bids.

- 10.3. If the eligibility requirements or statements, the bids, and all other documents for submission to the BAC are in foreign language other than English, it must be accompanied by a translation in English, which shall be authenticated by the appropriate Philippine foreign service establishment, post, or the equivalent office having jurisdiction over the foreign bidder's affairs in the Philippines. Similar to the required authentication above, for Contracting Parties to the Apostille Convention, only the translated documents shall be authenticated through an apostille pursuant to GPPB Resolution No. 13-2019 dated 23 May 2019. The English translation shall govern, for purposes of interpretation of the bid.

11. Documents comprising the Bid: Financial Component

- 11.1. The second bid envelope shall contain the financial documents for the Bid as specified in **Section VIII (Checklist of Technical and Financial Documents)**.
- 11.2. If the Bidder claims preference as a Domestic Bidder or Domestic Entity, a certification issued by DTI shall be provided by the Bidder in accordance with Section 43.1.3 of the 2016 revised IRR of RA No. 9184.
- 11.3. Any bid exceeding the ABC indicated in paragraph 1 of the **IB** shall not be accepted.
- 11.4. For Foreign-funded Procurement, a ceiling may be applied to bid prices provided the conditions are met under Section 31.2 of the 2016 revised IRR of RA No. 9184.

12. Bid Prices

- 12.1. Prices indicated on the Price Schedule shall be entered separately in the following manner:
- a. For Goods offered from within the Procuring Entity's country:
 - i. The price of the Goods quoted EXW (ex-works, ex-factory, ex-warehouse, ex-showroom, or off-the-shelf, as applicable);
 - ii. The cost of all customs duties and sales and other taxes already paid or payable;
 - iii. The cost of transportation, insurance, and other costs incidental to delivery of the Goods to their final destination; and
 - iv. The price of other (incidental) services, if any, listed in e.
 - b. For Goods offered from abroad:
 - i. Unless otherwise stated in the **BDS**, the price of the Goods shall be quoted delivered duty paid (DDP) with the place of destination in the Philippines as specified in the **BDS**. In quoting the price,

the Bidder shall be free to use transportation through carriers registered in any eligible country. Similarly, the Bidder may obtain insurance services from any eligible source country.

- ii. The price of other (incidental) services, if any, as listed in **Section VII (Technical Specifications)**.

13. Bid and Payment Currencies

13.1. For Goods that the Bidder will supply from outside the Philippines, the bid prices may be quoted in the local currency or tradeable currency accepted by the BSP at the discretion of the Bidder. However, for purposes of bid evaluation, Bids denominated in foreign currencies, shall be converted to Philippine currency based on the exchange rate as published in the BSP reference rate bulletin on the day of the bid opening.

13.2. Payment of the contract price shall be made in Philippine Pesos.

14. Bid Security

14.1. The Bidder shall submit a Bid Securing Declaration¹ or any form of Bid Security in the amount indicated in the **BDS**, which shall be not less than the percentage of the ABC in accordance with the schedule in the **BDS**.

14.2. The Bid and bid security shall be valid for One Hundred Twenty (120) calendar days from the date of the opening of bids. Any Bid not accompanied by an acceptable bid security shall be rejected by the Procuring Entity as non-responsive.

15. Sealing and Marking of Bids

Each bidder shall submit one copy of the first and second components of the Bid.

The Procuring Entity may request additional hard copies and/or electronic copies of the Bid. However, failure of the Bidders to comply with the said request shall not be a ground for disqualification.

If the Procuring Entity allows the submission of bids through online submission or any other electronic means, the Bidder shall submit an electronic copy of its Bid, which must be digitally signed. An electronic copy that cannot be opened or is corrupted shall be considered non-responsive and, thus, automatically disqualified.

16. Deadline for Submission of Bids

¹ In the case of Framework Agreement, the undertaking shall refer to entering into contract with the Procuring Entity and furnishing of the performance security or the performance securing declaration within ten (10) calendar days from receipt of Notice to Execute Framework Agreement.

- 16.1. The Bidders shall submit on the specified date and time and either at its physical address or through online submission as indicated in paragraph 7 of the **IB**.

17. Opening and Preliminary Examination of Bids

- 17.1. The BAC shall open the Bids in public at the time, on the date, and at the place specified in paragraph 9 of the **IB**. The Bidders' representatives who are present shall sign a register evidencing their attendance. In case videoconferencing, webcasting or other similar technologies will be used, attendance of participants shall likewise be recorded by the BAC Secretariat.

In case the Bids cannot be opened as scheduled due to justifiable reasons, the rescheduling requirements under Section 29 of the 2016 revised IRR of RA No. 9184 shall prevail.

- 17.2. The preliminary examination of bids shall be governed by Section 30 of the 2016 revised IRR of RA No. 9184.

18. Domestic Preference

- 18.1. The Procuring Entity will grant a margin of preference for the purpose of comparison of Bids in accordance with Section 43.1.2 of the 2016 revised IRR of RA No. 9184.

19. Detailed Evaluation and Comparison of Bids

- 19.1. The Procuring BAC shall immediately conduct a detailed evaluation of all Bids rated "*passed*," using non-discretionary pass/fail criteria. The BAC shall consider the conditions in the evaluation of Bids under Section 32.2 of the 2016 revised IRR of RA No. 9184.
- 19.2. If the Project allows partial bids, bidders may submit a proposal on any of the lots or items, and evaluation will be undertaken on a per lot or item basis, as the case maybe. In this case, the Bid Security as required by **ITB** Clause 15 shall be submitted for each lot or item separately.
- 19.3. The descriptions of the lots or items shall be indicated in **Section VII (Technical Specifications)**, although the ABCs of these lots or items are indicated in the **BDS** for purposes of the NFCC computation pursuant to Section 23.4.2.6 of the 2016 revised IRR of RA No. 9184. The NFCC must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder.
- 19.4. The Project shall be awarded as one Project having several items that shall be awarded as one contract.
- 19.5. Except for bidders submitting a committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation, all Bids must include the NFCC computation pursuant to Section 23.4.1.4 of the 2016 revised IRR of RA No. 9184, which must be sufficient for the total of the ABCs for all the lots or items participated in by the prospective Bidder. For bidders submitting the

committed Line of Credit, it must be at least equal to ten percent (10%) of the ABCs for all the lots or items participated in by the prospective Bidder.

20. Post-Qualification

- 20.1. Within a non-extendible period of five (5) calendar days from receipt by the Bidder of the notice from the BAC that it submitted the Lowest Calculated Bid, the Bidder shall submit its latest income and business tax returns filed and paid through the BIR Electronic Filing and Payment System (eFPS) and other appropriate licenses and permits required by law and stated in the **BDS**.

21. Signing of the Contract

- 21.1. The documents required in Section 37.2 of the 2016 revised IRR of RA No. 9184 shall form part of the Contract. Additional Contract documents are indicated in the **BDS**.

Bid Data Sheet

ITB Clause	
5.3	<p>For this purpose, contracts similar to the Project shall be:</p> <ul style="list-style-type: none"> a. contract for the supply and delivery of generator sets and/or supply, delivery, installation and commissioning of generator sets. b. completed within five (5) years prior to the deadline for the submission and receipt of bids.
7.1	Subcontracting is not allowed.
12	The price of the Goods shall be quoted DDP <i>[Manila]</i> or the applicable International Commercial Terms (INCOTERMS) for this Project.
14.1	<p>The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts:</p> <ul style="list-style-type: none"> a. The amount of not less than Nine Million Pesos (Php9,000,000.00), if bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit; or b. The amount of not less than Twenty-Two Million Five Hundred Thousand Pesos (Php22,500,000.00) if bid security is in Surety Bond.
15	<p>Each Bidder shall submit ONE (1) original and SIX (6) copies of its Technical and Financial Components of its Bid in two (2) separate sealed bid envelopes, which should be submitted simultaneously. Each of the bid documents should be individually sealed.</p> <p>All bid documents shall be book-bound, hard-bound and properly labelled with index tabs.</p>
19.3	Partial bid is not allowed. The goods are grouped in a single lot and the lot shall not be divided into sub-lots for the purpose of bidding, evaluation, and contract award.
20.2	No additional requirements.
21.2	No additional requirements.

Section IV. General Conditions of Contract

1. Scope of Contract

This Contract shall include all such items, although not specifically mentioned, that can be reasonably inferred as being required for its completion as if such items were expressly mentioned herein. All the provisions of RA No. 9184 and its 2016 revised IRR, including the Generic Procurement Manual, and associated issuances, constitute the primary source for the terms and conditions of the Contract, and thus, applicable in contract implementation. Herein clauses shall serve as the secondary source for the terms and conditions of the Contract.

This is without prejudice to Sections 74.1 and 74.2 of the 2016 revised IRR of RA No. 9184 allowing the GPPB to amend the IRR, which shall be applied to all procurement activities, the advertisement, posting, or invitation of which were issued after the effectivity of the said amendment.

Additional requirements for the completion of this Contract shall be provided in the **Special Conditions of Contract (SCC)**.

2. Advance Payment and Terms of Payment

2.1. Advance payment of the contract amount is provided under Annex “D” of the revised 2016 IRR of RA No. 9184.

2.2. The Procuring Entity is allowed to determine the terms of payment on the partial or staggered delivery of the Goods procured, provided such partial payment shall correspond to the value of the goods delivered and accepted in accordance with prevailing accounting and auditing rules and regulations. The terms of payment are indicated in the SCC.

3. Performance Security

Within ten (10) calendar days from receipt of the Notice of Award by the Bidder from the Procuring Entity but in no case later than prior to the signing of the Contract by both parties, the successful Bidder shall furnish the performance security in any of the forms prescribed in Section 39 of the 2016 revised IRR of RA No. 9184.

4. Inspection and Tests

The Procuring Entity or its representative shall have the right to inspect and/or to test the Goods to confirm their conformity to the Project specifications at no extra cost to the Procuring Entity in accordance with the Generic Procurement Manual. In addition to tests in the SCC, **Section IV (Technical Specifications)** shall specify what inspections and/or tests the Procuring Entity requires, and where they are to be conducted. The Procuring Entity shall notify the Supplier in writing, in a timely manner, of the identity of any representatives retained for these purposes.

All reasonable facilities and assistance for the inspection and testing of Goods, including access to drawings and production data, shall be provided by the Supplier to the authorized inspectors at no charge to the Procuring Entity.

5. Warranty

- 6.1. In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier as provided under Section 62.1 of the 2016 revised IRR of RA No. 9184.
- 6.2. The Procuring Entity shall promptly notify the Supplier in writing of any claims arising under this warranty. Upon receipt of such notice, the Supplier shall, repair or replace the defective Goods or parts thereof without cost to the Procuring Entity, pursuant to the Generic Procurement Manual.

6. Liability of the Supplier

The Supplier's liability under this Contract shall be as provided by the laws of the Republic of the Philippines.

If the Supplier is a joint venture, all partners to the joint venture shall be jointly and severally liable to the Procuring Entity.

Section V. Special Conditions of Contract

Special Conditions of Contract

GCC Clause																										
1	<p>Delivery and Documents –</p> <p>For purposes of the Contract, “EXW,” “FOB,” “FCA,” “CIF,” “CIP,” “DDP” and other trade terms used to describe the obligations of the parties shall have the meanings assigned to them by the current edition of INCOTERMS published by the International Chamber of Commerce, Paris. The Delivery terms of this Contract shall be as follows:</p> <p><i>[For Goods supplied from abroad, state:]</i> “The delivery terms applicable to the Contract are DDP delivered <i>[indicate place of destination]</i>. In accordance with INCOTERMS.”</p> <p><i>For Goods supplied from within the Philippines, state:]</i> “The delivery terms applicable to this Contract are delivered <i>[indicate place of destination]</i>. Risk and title will pass from the Supplier to the Procuring Entity upon receipt and final acceptance of the Goods at their final destination.”</p> <p>Delivery of the Goods shall be made by the Supplier in accordance with the terms specified in Section VI (Schedule of Requirements).</p> <p>For purposes of this Clause the Procuring Entity’s Representatives at the Project Sites are the following:</p> <table><tr><th></th><th>PMO</th><th>Deployment</th></tr><tr><td rowspan="3">1</td><td rowspan="3">Zamboanga</td><td>Port of Ipil TMO Zamboanga Sibugay</td></tr><tr><td>Port of Malangas, TMO Zamboanga Sibugay</td></tr><tr><td>Port of Margosatubig, TMO Zamboanga del Sur</td></tr><tr><td rowspan="4">2</td><td rowspan="4">Masbate</td><td>TMO San Pascual</td></tr><tr><td>Port of Aroroy</td></tr><tr><td>Baseport</td></tr><tr><td>Port of Claveria</td></tr><tr><td rowspan="4">3</td><td rowspan="4">Western Leyte / Biliran</td><td>POB Port of Ormoc</td></tr><tr><td>POB Port of Maasin</td></tr><tr><td>POB Port of Palompon</td></tr><tr><td>TMO Isabel</td></tr><tr><td rowspan="3">4</td><td rowspan="3">DAVAO</td><td>TMO Babak</td></tr><tr><td>TMO Malalag</td></tr><tr><td>TMO Mati</td></tr></table>		PMO	Deployment	1	Zamboanga	Port of Ipil TMO Zamboanga Sibugay	Port of Malangas, TMO Zamboanga Sibugay	Port of Margosatubig, TMO Zamboanga del Sur	2	Masbate	TMO San Pascual	Port of Aroroy	Baseport	Port of Claveria	3	Western Leyte / Biliran	POB Port of Ormoc	POB Port of Maasin	POB Port of Palompon	TMO Isabel	4	DAVAO	TMO Babak	TMO Malalag	TMO Mati
	PMO	Deployment																								
1	Zamboanga	Port of Ipil TMO Zamboanga Sibugay																								
		Port of Malangas, TMO Zamboanga Sibugay																								
		Port of Margosatubig, TMO Zamboanga del Sur																								
2	Masbate	TMO San Pascual																								
		Port of Aroroy																								
		Baseport																								
		Port of Claveria																								
3	Western Leyte / Biliran	POB Port of Ormoc																								
		POB Port of Maasin																								
		POB Port of Palompon																								
		TMO Isabel																								
4	DAVAO	TMO Babak																								
		TMO Malalag																								
		TMO Mati																								

	5	Surigao	TMO Siargao
			TMO Lipata
	6	Misamis Oriental/ Cagayan de Oro	TMO Balingoan
			TMO Opol
	7	Misamis Occidental/Ozamis	TMO Jimenez
	8	NCR North	TMO Vitas
	9	Marquez	Port of Bulacan
			Port of Cawit
	10	Bataan/Aurora	Port of Dingalan, Aurora
	11	Northern Luzon	Port of Claveria, Cagayan
	11	Eastern Leyte/Samar	TMO Borongon
			TMO Calbayog
			TMO Guiuan
			TMO San Isidro
			Port of San Ricardo
			TMO Catbalogan
	12	Panay/Guimaras	Baseport
	13	SOCSARGEN	Baseport
	14	Bicol	TMO Matnog
	15	Batangas	Port of San Juan
			Port of Calatagan
			Port of Nasugbu
			Port of Ambulong
	16		PTB of Dumaguete

	Negros Oriental/ Siquijor	POB of Dumaguete
		PTB, Port of Larena
		PTB, Port of Lazi

Incidental Services –

The Supplier is required to provide all of the following services, including additional services, if any, specified in Section VI. Schedule of Requirements:

- a. performance or supervision of on-site assembly and/or start-up of the supplied Goods;
- b. furnishing of tools required for assembly and/or maintenance of the supplied Goods;
- c. furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied Goods;
- d. performance or supervision or maintenance and/or repair of the supplied Goods, for a period of time agreed by the parties, provided that this service shall not relieve the Supplier of any warranty obligations under this Contract;
- e. Provide quarterly preventive maintenance service within the two year warranty period;
- f. Conduct a Generator Set Unit Orientation and Preventive Maintenance Seminar; and
- g. Provisions for the following:
 - i. Set of Tools, Operating and Parts Manual;
 - ii. Initial Diesel in tank for testing, upon delivery of Generator Set;
 - iii. Anti-vibration rubber or platform for free for PMOs/TMOs without existing pedestal; and
 - iv. Complete installation of generator sets, ATS breakers, High Amperage Cables, Synchronizing Panel (PMO-Socsargen), Terminal lugs, Solderless Connectors, Copper Bus Bar, Pipe/Conduits and other accessories with testing and commissioning of forty-two units per PMOs as listed and described in Item No. 5 of the Terms of Reference.

The Contract price for the Goods shall include the prices charged by the Supplier for incidental services and shall not exceed the prevailing rates charged to other parties by the Supplier for similar services.

Spare Parts –

The Supplier is required to provide all of the following materials, notifications, and information pertaining to spare parts manufactured or distributed by the Supplier:

a. such spare parts as the Procuring Entity may elect to purchase from the Supplier, provided that this election shall not relieve the Supplier of any warranty obligations under this Contract; and

b. in the event of termination of production of the spare parts:

- i. advance notification to the Procuring Entity of the pending termination, in sufficient time to permit the Procuring Entity to procure needed requirements; and
- ii. following such termination, furnishing at no cost to the Procuring Entity, the blueprints, drawings, and specifications of the spare parts, if requested.

The spare parts and other components required are listed in **Section VI (Schedule of Requirements)** and the cost thereof are included in the contract price.

The Supplier shall carry sufficient inventories to assure ex-stock supply of consumable spare parts or components for the Goods for a period of ten (10) years after the last day of manufacturing of the specific model.

Spare parts or components shall be supplied as promptly as possible, but in any case, within two (2) months of placing the order.

Packaging –

The Supplier shall provide such packaging of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in this Contract. The packaging shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit, and open storage. Packaging case size and weights shall take into consideration, where appropriate, the remoteness of the Goods' final destination and the absence of heavy handling facilities at all points in transit.

The packaging, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract, including additional requirements, if any, specified below, and in any subsequent instructions ordered by the Procuring Entity.

The outer packaging must be clearly marked on at least four (4) sides as follows:

Name of the Procuring Entity

Name of the Supplier

Contract Description

Final Destination

Gross weight

Any special lifting instructions

Any special handling instructions

Any relevant HAZCHEM classifications

	<p>A packaging list identifying the contents and quantities of the package is to be placed on an accessible point of the outer packaging if practical. If not practical the packaging list is to be placed inside the outer packaging but outside the secondary packaging.</p> <p>Transportation –</p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP, or DDP, transport of the Goods to the port of destination or such other named place of destination in the Philippines, as shall be specified in this Contract, shall be arranged and paid for by the Supplier, and the cost thereof shall be included in the Contract Price.</p> <p>Where the Supplier is required under this Contract to transport the Goods to a specified place of destination within the Philippines, defined as the Project Site, transport to such place of destination in the Philippines, including insurance and storage, as shall be specified in this Contract, shall be arranged by the Supplier, and related costs shall be included in the contract price.</p> <p>Where the Supplier is required under Contract to deliver the Goods CIF, CIP or DDP, Goods are to be transported on carriers of Philippine registry. In the event that no carrier of Philippine registry is available, Goods may be shipped by a carrier which is not of Philippine registry provided that the Supplier obtains and presents to the Procuring Entity certification to this effect from the nearest Philippine consulate to the port of dispatch. In the event that carriers of Philippine registry are available but their schedule delays the Supplier in its performance of this Contract the period from when the Goods were first ready for shipment and the actual date of shipment the period of delay will be considered force majeure.</p> <p>The Procuring Entity accepts no liability for the damage of Goods during transit other than those prescribed by INCOTERMS for DDP deliveries. In the case of Goods supplied from within the Philippines or supplied by domestic Suppliers risk and title will not be deemed to have passed to the Procuring Entity until their receipt and final acceptance at the final destination.</p> <p>Intellectual Property Rights –</p> <p>The Supplier shall indemnify the Procuring Entity against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the Goods or any part thereof.</p>
2.2	<p>The terms of payment shall be as follows:</p> <ul style="list-style-type: none"> • 65% of contract cost – After inspection and acceptance by PPA Head Office.

	<ul style="list-style-type: none"> • 35% of contract cost – After installation, commissioning, inspection and acceptance by PMOs
4	The equipment shall be tested (on/off and running for at least 10 minutes) after installation at the respective PMOs per deployment list.

Section VI. Schedule of Requirements

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item Number	Description²	Quantity	Total	Delivered, Weeks/Months
	Supply, Delivery, Installation, Testing and Commissioning of Generator Sets (Phase 2)	42 units	42 units	Inspection of the units by PPA Head Office Representatives at the Supplier's Warehouse within Metro Manila within ninety (90) calendar days from receipt of the Notice to Proceed.
	Delivery, installation, testing and commissioning at the PMOs. ³	42 units	42 units	Within sixty (60) days after inspection and acceptance by the PPA Head Office Representatives.

² Subject to the Technical Specifications under Item No. V of the Terms of Reference

³ In accordance with the Deployment Schedule under Item No. III of the Terms of Reference

Section VII. Technical Specifications

Technical Specifications

Item	Specification	Statement of Compliance
		<p><i>[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be</i></p>

		<i>false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]</i>										
	SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF GENERATOR SETS (PHASE 2) IN ACCORDANCE WITH THE DEPLOYMENT SCHEDULE UNDER ITEM III OF THE TERMS OF REFERENCE											
	SCOPE OF WORK 1. Supply and delivery of the brand new generator sets and Automatic Transfer Switch (ATS). 2. Mobilization of manpower, equipment and technical supervisions. 3. Installation of the equipment at the designated deployment ports. 4. Testing and commissioning of the equipment per port or terminal.											
	TECHNICAL SPECIFICATIONS – GENERATOR SETS											
	1. One (1) unit 75kVA Generator Set Port of Ipil, TMO-Zamboanga Sibugay <table border="1"><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>54kW/68kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>60kW/75kVA</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	54kW/68kVA	Standby Rating Power (kW/kVA)	60kW/75kVA	
Number of cylinders	4											
Cylinder arrangement	In-Line											
Aspiration	Turbocharged after-water cooling											
Prime Rating Power (kW/kVA)	54kW/68kVA											
Standby Rating Power (kW/kVA)	60kW/75kVA											

	<table><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>120L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	120L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Control Panel	Digital																											
Speed governor	Electronic																											
Cooling system	Water Cooling Cycle																											
Phase	3																											
Rpm	1800																											
Volts	230Vac																											
Frequency	60hZ																											
Power Factor	0.8																											
Fuel consumption at 100% load (L/H)	15.9L/H																											
Fuel Tank Capacity	120L																											
Insulation	Class H																											
Starter motor	24V																											
Exciter type	Single bearing, Brushless, Self-excited																											
2. One (1) unit 75kVA Generator Set Port of Malangas, TMO-Zamboanga Sibugay	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>54kW/68kVA</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	54kW/68kVA																			
Number of cylinders	4																											
Cylinder arrangement	In-Line																											
Aspiration	Turbocharged after-water cooling																											
Prime Rating Power (kW/kVA)	54kW/68kVA																											

	Standby Rating Power (kW/kVA)	60kW/75kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	15.9L/H
	Fuel Tank Capacity	120L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
3. One (1) unit 75kVA Generator Set		
Port of Margosatubig, TMO-Zamboanga Del Sur		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	54kW/68kVA

	Standby Rating Power (kW/kVA)	60kW/75kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	15.9L/H
	Fuel Tank Capacity	120L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
4. One (1) unit 10KVA Generator Set Port of San Pascual, PMO Masbate		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Naturally Aspirated
	Prime Rating Power (kW/kVA)	7.2kW/9kVA

	Standby Rating Power (kW/kVA)	8kW/10kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	8.6L/H
	Fuel Tank Capacity	85L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
5. One (1) unit 10 KVA Generator Set Port of Aroroy, PMO Masbate		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Naturally Aspirated
	Prime Rating Power (kW/kVA)	7.2kW/9kVA

	Standby Rating Power (kW/kVA)	8kW/10kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	8.6L/H
	Fuel Tank Capacity	85L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
6. One (1) unit 150 KVA Generator Set Baseport PMO Masbate		
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	109kW/136kVA

	Standby Rating Power (kW/kVA)	120kW/150kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	34L/H
	Fuel Tank Capacity	250L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
	7. One (1) unit 10 KVA Generator Set Port of Claveria, PMO Masbate	
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Naturally Aspirated
	Prime Rating Power (kW/kVA)	7.2kW/9kVA

	Standby Rating Power (kW/kVA)	8kW/10kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	8.6L/H
	Fuel Tank Capacity	85L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
	8. One (1) unit 500 KVA Generator Set POB Port of Ormoc, PMO Western Leyte/Biliran	
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling

	Prime Rating Power (kW/kVA)	363kW/454kVA	
	Standby Rating Power (kW/kVA)	400kW/500kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	104L/H	
	Fuel Tank Capacity	850L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
	9. One (1) unit 200 KVA Generator Set POB Port of Maasin, PMO Western Leyte/Biliran		
	Number of cylinders	6	
	Cylinder arrangement	In-Line	

	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	144kW/180kVA
	Standby Rating Power (kW/kVA)	160kW/200kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	49L/H
	Fuel Tank Capacity	350L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
	10. One (1) unit 200 KVA Generator Set POB Port of Palompon, PMO Western Leyte/Biliran	

	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	144kW/180kVA
	Standby Rating Power (kW/kVA)	160kW/200kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	49L/H
	Fuel Tank Capacity	350L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited

**11. One (1) unit 30 KVA Generator Set
TMO-Isabel, PMO Western Leyte/Biliran**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Naturally Aspirated
Prime Rating Power (kW/kVA)	21.6kW/27kVA
Standby Rating Power (kW/kVA)	24kW/30kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	8.6/H
Fuel Tank Capacity	85L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**12. One (1) unit 150 KVA Generator Set
TMO BABAK, PMO-Davao**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	109kW/136kVA
Standby Rating Power (kW/kVA)	120kW/150kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**13. One (1) unit 150 KVA Generator Set
TMO MALALAG, PMO-Davao**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	109kW/136kVA
Standby Rating Power (kW/kVA)	120kW/150kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**14. One (1) unit 150 KVA Generator Set
TMO MATI, PMO-Davao**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	109kW/136kVA
Standby Rating Power (kW/kVA)	120kW/150kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**15. One (1) unit 50 KVA Generator Set
TMO SIARGAO, PMO-Surigao del Norte**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	36kW/45kVA
Standby Rating Power (kW/kVA)	40kW/50kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	15.9L/H
Fuel Tank Capacity	85L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**16. One (1) unit 50 KVA Generator Set
TMO LIPATA, PMO-Surigao del Norte**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	36kW/45kVA
Standby Rating Power (kW/kVA)	40kW/50kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	15.9L/H
Fuel Tank Capacity	85L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**17. One (1) unit 300 KVA Generator Set
TMO Balingoan, PMO-Misamis Oriental/
Cagayan de Oro**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	218kW/273kVA
Standby Rating Power (kW/kVA)	240kW/300kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	62L/H
Fuel Tank Capacity	480L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**18. One (1) unit 200 KVA Generator Set
TMO OPOL, PMO-Misamis Oriental/Cagayan
de Oro**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after- water cooling
Prime Rating Power (kW/kVA)	144kW/180kVA
Standby Rating Power (kW/kVA)	160kW/200kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	49L/H
Fuel Tank Capacity	350L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**19. One (1) unit 75 KVA Generator Set
TMO JIMENEZ, PMO-Misamis Oriental/
Cagayan de Oro**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	54kW/68kVA
Standby Rating Power (kW/kVA)	60kW/75kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	15.9L/H
Fuel Tank Capacity	120L
Insulation	Class H

	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
20. One (1) unit 50 KVA Generator Set TMO VITAS, NCR-North		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after-water cooling
	Prime Rating Power (kW/kVA)	36kW/45kVA
	Standby Rating Power (kW/kVA)	40kW/50kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	15.9L/H
	Fuel Tank Capacity	85L
	Insulation	Class H

	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
21. One (1) unit 250 KVA Generator Set Port of Bulacan, PMO-Marquez		
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after- water cooling
	Prime Rating Power (kW/kVA)	182kW/227kVA
	Standby Rating Power (kW/kVA)	200kW/250kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	59L/H
	Fuel Tank Capacity	350L

	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
22. One (1) unit 150 KVA Generator Set Port of Cawit, PMO-Marquez		
	Number of cylinders	6
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after- water cooling
	Prime Rating Power (kW/kVA)	109kW/136kVA
	Standby Rating Power (kW/kVA)	120kW/150kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	34L/H
	Fuel Tank Capacity	250L

	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
23. One (1) unit 50 KVA Generator Set PORT OF DINGALAN, PMO-Bataan, Aurora		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Turbocharged after- water cooling
	Prime Rating Power (kW/kVA)	36kW/45kVA
	Standby Rating Power (kW/kVA)	40kW/50kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	15.9L/H
	Fuel Tank Capacity	85L

	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
24. One (1) unit 35 KVA Generator Set Port of Claveria, PMO Cagayan, Northern Luzon		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Naturally Aspirated
	Prime Rating Power (kW/kVA)	25.2kW/31.5kVA
	Standby Rating Power (kW/kVA)	28kW/35kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	8.6/H
	Fuel Tank Capacity	85L
	Insulation	Class H

	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited
25. One (1) unit 10 KVA Generator Set TMO BORONGAN, PMO-Eastern Leyte/Samar		
	Number of cylinders	4
	Cylinder arrangement	In-Line
	Aspiration	Naturally Aspirated
	Prime Rating Power (kW/kVA)	7.2kW/9kVA
	Standby Rating Power (kW/kVA)	8kW/10kVA
	Control Panel	Digital
	Speed governor	Electronic
	Cooling system	Water Cooling Cycle
	Phase	3
	Rpm	1800
	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8

	<table><tr><td>Fuel consumption at 100% load (L/H)</td><td>8.6L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Fuel consumption at 100% load (L/H)	8.6L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited																	
Fuel consumption at 100% load (L/H)	8.6L/H																											
Fuel Tank Capacity	85L																											
Insulation	Class H																											
Starter motor	24V																											
Exciter type	Single bearing, Brushless, Self-excited																											
26. One (1) unit 150 KVA Generator Set TMO CALBAYOG, PMO-Eastern Leyte/Samar																												
	<table><tr><td>Number of cylinders</td><td>6</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>109kW/136kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>120kW/150kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr></table>	Number of cylinders	6	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	109kW/136kVA	Standby Rating Power (kW/kVA)	120kW/150kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	
Number of cylinders	6																											
Cylinder arrangement	In-Line																											
Aspiration	Turbocharged after-water cooling																											
Prime Rating Power (kW/kVA)	109kW/136kVA																											
Standby Rating Power (kW/kVA)	120kW/150kVA																											
Control Panel	Digital																											
Speed governor	Electronic																											
Cooling system	Water Cooling Cycle																											
Phase	3																											
Rpm	1800																											
Volts	230Vac																											
Frequency	60hZ																											
Power Factor	0.8																											

	<table><tr><td>Fuel consumption at 100% load (L/H)</td><td>34L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>250L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Fuel consumption at 100% load (L/H)	34L/H	Fuel Tank Capacity	250L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited																	
Fuel consumption at 100% load (L/H)	34L/H																											
Fuel Tank Capacity	250L																											
Insulation	Class H																											
Starter motor	24V																											
Exciter type	Single bearing, Brushless, Self-excited																											
27. One (1) unit 10 KVA Generator Set TMO GUIUAN, PMO-Eastern Leyte/Samar																												
	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Naturally Aspirated</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>7.2kW/9kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>8kW/10kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Naturally Aspirated	Prime Rating Power (kW/kVA)	7.2kW/9kVA	Standby Rating Power (kW/kVA)	8kW/10kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	
Number of cylinders	4																											
Cylinder arrangement	In-Line																											
Aspiration	Naturally Aspirated																											
Prime Rating Power (kW/kVA)	7.2kW/9kVA																											
Standby Rating Power (kW/kVA)	8kW/10kVA																											
Control Panel	Digital																											
Speed governor	Electronic																											
Cooling system	Water Cooling Cycle																											
Phase	3																											
Rpm	1800																											
Volts	230Vac																											
Frequency	60hZ																											
Power Factor	0.8																											

	Fuel consumption at 100% load (L/H)	8.6L/H	
	Fuel Tank Capacity	85L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
28. One (1) unit 150 KVA Generator Set TMO SAN ISIDRO, PMO-Eastern Leyte/Samar			
	Number of cylinders	6	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after-water cooling	
	Prime Rating Power (kW/kVA)	109kW/136kVA	
	Standby Rating Power (kW/kVA)	120kW/150kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	

Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

29. One (1) unit 150 KVA Generator Set PORT OF SAN RICARDO, PMO-Eastern Leyte/ Samar	
Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after- water cooling
Prime Rating Power (kW/kVA)	109kW/136kVA
Standby Rating Power (kW/kVA)	120kW/150kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ

	<table><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>34L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>250L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Power Factor	0.8	Fuel consumption at 100% load (L/H)	34L/H	Fuel Tank Capacity	250L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited											
Power Factor	0.8																							
Fuel consumption at 100% load (L/H)	34L/H																							
Fuel Tank Capacity	250L																							
Insulation	Class H																							
Starter motor	24V																							
Exciter type	Single bearing, Brushless, Self-excited																							
30. One (1) unit 500 KVA Generator Set TMO CATBALOGAN, PMO-Eastern Leyte/ Samar																								
	<table><tr><td>Number of cylinders</td><td>6</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>363kW/454kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>400kW/500kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr></table>	Number of cylinders	6	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	363kW/454kVA	Standby Rating Power (kW/kVA)	400kW/500kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	Rpm	1800	Volts	230Vac	
Number of cylinders	6																							
Cylinder arrangement	In-Line																							
Aspiration	Turbocharged after-water cooling																							
Prime Rating Power (kW/kVA)	363kW/454kVA																							
Standby Rating Power (kW/kVA)	400kW/500kVA																							
Control Panel	Digital																							
Speed governor	Electronic																							
Cooling system	Water Cooling Cycle																							
Phase	3																							
Rpm	1800																							
Volts	230Vac																							

	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	104L/H	
	Fuel Tank Capacity	850L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	

31. One (1) unit 50 KVA Generator Set PMO-Panay/Guimaras Baseport			
Number of cylinders	4		
Cylinder arrangement	In-Line		
Aspiration	Turbocharged after-water cooling		
Prime Rating Power (kW/kVA)	36kW/45kVA		
Standby Rating Power (kW/kVA)	40kW/50kVA		
Control Panel	Digital		
Speed governor	Electronic		
Cooling system	Water Cooling Cycle		
Phase	3		
Rpm	1800		

	Volts	230Vac
	Frequency	60hZ
	Power Factor	0.8
	Fuel consumption at 100% load (L/H)	15.9L/H
	Fuel Tank Capacity	85L
	Insulation	Class H
	Starter motor	24V
	Exciter type	Single bearing, Brushless, Self-excited

32. A. One (1) unit 350 KVA Generator Set & B. One (1) unit 250 KVA Generator Set with Synchronizer																
PMO-SOCSARGEN BASEPORT																
A. 350 KVA Generator Set																
<table><tr><td>Number of cylinders</td><td>6</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>252kW/315kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>280kW/350kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr></table>	Number of cylinders	6	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	252kW/315kVA	Standby Rating Power (kW/kVA)	280kW/350kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle
Number of cylinders	6															
Cylinder arrangement	In-Line															
Aspiration	Turbocharged after-water cooling															
Prime Rating Power (kW/kVA)	252kW/315kVA															
Standby Rating Power (kW/kVA)	280kW/350kVA															
Control Panel	Digital															
Speed governor	Electronic															
Cooling system	Water Cooling Cycle															

	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	62L/H	
	Fuel Tank Capacity	480L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	
	B. 250 KVA Generator Set		
	Number of cylinders	6	
	Cylinder arrangement	In-Line	
	Aspiration	Turbocharged after- water cooling	
	Prime Rating Power (kW/kVA)	182kW/227kVA	
	Standby Rating Power (kW/kVA)	200kW/250kVA	
	Control Panel	Digital	
	Speed governor	Electronic	
	Cooling system	Water Cooling Cycle	
	Phase	3	

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>59L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>350L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	59L/H	Fuel Tank Capacity	350L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	59L/H																			
Fuel Tank Capacity	350L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
33. One (1) unit 250 KVA Generator Set Port of Matnog, PMO-Bicol																				
	<table><tr><td>Number of cylinders</td><td>6</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>182kW/227kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>200kW/250kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr></table>	Number of cylinders	6	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	182kW/227kVA	Standby Rating Power (kW/kVA)	200kW/250kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	
Number of cylinders	6																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	182kW/227kVA																			
Standby Rating Power (kW/kVA)	200kW/250kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			
Phase	3																			

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>59L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>350L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	59L/H	Fuel Tank Capacity	350L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	59L/H																			
Fuel Tank Capacity	350L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
34. One (1) unit 50 KVA Generator Set Port of San Juan, PMO-Batangas																				
	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>36kW/45kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>40kW/50kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	36kW/45kVA	Standby Rating Power (kW/kVA)	40kW/50kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	
Number of cylinders	4																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	36kW/45kVA																			
Standby Rating Power (kW/kVA)	40kW/50kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			
Phase	3																			

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	15.9L/H																			
Fuel Tank Capacity	85L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
35. One (1) unit 50 KVA Generator Set Port of Calatagan, PMO-Batangas																				
	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>36kW/45kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>40kW/50kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	36kW/45kVA	Standby Rating Power (kW/kVA)	40kW/50kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	
Number of cylinders	4																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	36kW/45kVA																			
Standby Rating Power (kW/kVA)	40kW/50kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			
Phase	3																			

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	15.9L/H																			
Fuel Tank Capacity	85L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
36. One (1) unit 50 KVA Generator Set Port of Nasugbu, PMO-Batangas																				
	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>36kW/45kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>40kW/50kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	36kW/45kVA	Standby Rating Power (kW/kVA)	40kW/50kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	
Number of cylinders	4																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	36kW/45kVA																			
Standby Rating Power (kW/kVA)	40kW/50kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			
Phase	3																			

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	15.9L/H																			
Fuel Tank Capacity	85L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
37. One (1) unit 50 KVA Generator Set Port of Ambulong, PMO-Batangas																				
	<table><tr><td>Number of cylinders</td><td>4</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>36kW/45kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>40kW/50kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr><tr><td>Phase</td><td>3</td></tr></table>	Number of cylinders	4	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	36kW/45kVA	Standby Rating Power (kW/kVA)	40kW/50kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle	Phase	3	
Number of cylinders	4																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	36kW/45kVA																			
Standby Rating Power (kW/kVA)	40kW/50kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			
Phase	3																			

	<table><tr><td>Rpm</td><td>1800</td></tr><tr><td>Volts</td><td>230Vac</td></tr><tr><td>Frequency</td><td>60hZ</td></tr><tr><td>Power Factor</td><td>0.8</td></tr><tr><td>Fuel consumption at 100% load (L/H)</td><td>15.9L/H</td></tr><tr><td>Fuel Tank Capacity</td><td>85L</td></tr><tr><td>Insulation</td><td>Class H</td></tr><tr><td>Starter motor</td><td>24V</td></tr><tr><td>Exciter type</td><td>Single bearing, Brushless, Self-excited</td></tr></table>	Rpm	1800	Volts	230Vac	Frequency	60hZ	Power Factor	0.8	Fuel consumption at 100% load (L/H)	15.9L/H	Fuel Tank Capacity	85L	Insulation	Class H	Starter motor	24V	Exciter type	Single bearing, Brushless, Self-excited	
Rpm	1800																			
Volts	230Vac																			
Frequency	60hZ																			
Power Factor	0.8																			
Fuel consumption at 100% load (L/H)	15.9L/H																			
Fuel Tank Capacity	85L																			
Insulation	Class H																			
Starter motor	24V																			
Exciter type	Single bearing, Brushless, Self-excited																			
38. One (1) unit 200 KVA Generator Set PTB DUMAGUETE, PMO-Negros Oriental/ Siquijor																				
	<table><tr><td>Number of cylinders</td><td>6</td></tr><tr><td>Cylinder arrangement</td><td>In-Line</td></tr><tr><td>Aspiration</td><td>Turbocharged after-water cooling</td></tr><tr><td>Prime Rating Power (kW/kVA)</td><td>144kW/180kVA</td></tr><tr><td>Standby Rating Power (kW/kVA)</td><td>160kW/200kVA</td></tr><tr><td>Control Panel</td><td>Digital</td></tr><tr><td>Speed governor</td><td>Electronic</td></tr><tr><td>Cooling system</td><td>Water Cooling Cycle</td></tr></table>	Number of cylinders	6	Cylinder arrangement	In-Line	Aspiration	Turbocharged after-water cooling	Prime Rating Power (kW/kVA)	144kW/180kVA	Standby Rating Power (kW/kVA)	160kW/200kVA	Control Panel	Digital	Speed governor	Electronic	Cooling system	Water Cooling Cycle			
Number of cylinders	6																			
Cylinder arrangement	In-Line																			
Aspiration	Turbocharged after-water cooling																			
Prime Rating Power (kW/kVA)	144kW/180kVA																			
Standby Rating Power (kW/kVA)	160kW/200kVA																			
Control Panel	Digital																			
Speed governor	Electronic																			
Cooling system	Water Cooling Cycle																			

	Phase	3	
	Rpm	1800	
	Volts	230Vac	
	Frequency	60hZ	
	Power Factor	0.8	
	Fuel consumption at 100% load (L/H)	49L/H	
	Fuel Tank Capacity	350L	
	Insulation	Class H	
	Starter motor	24V	
	Exciter type	Single bearing, Brushless, Self-excited	

**39. One (1) unit 500 KVA Generator Set
POB DUMAGUETE, PMO-Negros Oriental/
Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	363kW/454kVA
Standby Rating Power (kW/kVA)	400kW/500kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	104L/H
Fuel Tank Capacity	850L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**40. One (1) unit 150 KVA Generator Set
PTB PORT OF LARENA, PMO-Negros
Oriental/ Siquijor**

Number of cylinders	6
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	109kW/136kVA
Standby Rating Power (kW/kVA)	120kW/150kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	34L/H
Fuel Tank Capacity	250L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

**41. One (1) unit 100 KVA Generator Set
Port of Lazi, PMO-Negros Oriental/ Siquijor**

Number of cylinders	4
Cylinder arrangement	In-Line
Aspiration	Turbocharged after-water cooling
Prime Rating Power (kW/kVA)	73kW/91kVA
Standby Rating Power (kW/kVA)	80kW/100kVA
Control Panel	Digital
Speed governor	Electronic
Cooling system	Water Cooling Cycle
Phase	3
Rpm	1800
Volts	230Vac
Frequency	60hZ
Power Factor	0.8
Fuel consumption at 100% load (L/H)	20.1L/H
Fuel Tank Capacity	150L
Insulation	Class H
Starter motor	24V
Exciter type	Single bearing, Brushless, Self-excited

	<table><tr><th>KVA</th><th>SOUND LEVEL</th></tr><tr><td>10 - 30</td><td>75dBA@7m</td></tr><tr><td>45 - 300</td><td>80dBA@7m</td></tr><tr><td>500 - 1000</td><td>90dBA@7m</td></tr></table>	KVA	SOUND LEVEL	10 - 30	75dBA@7m	45 - 300	80dBA@7m	500 - 1000	90dBA@7m	
KVA	SOUND LEVEL									
10 - 30	75dBA@7m									
45 - 300	80dBA@7m									
500 - 1000	90dBA@7m									
	TECHNICAL SPECIFICATIONS – GENERATOR SETS 1. 230 volts, 3 phase, wall-mounted/free standing with NEMA enclosure equal to the capacity of the generator set. 2. Transfer switched based on Molded-Case-Switch components. 3. All Generator sets must come with anti-vibration rubber pads.									
	WARRANTY 1. One (1) year warranty for manufacturing defects from the date of receipt of the Certificate of Acceptance. 2. Two (2) years warranty for parts and services from the date of receipt of the Certificate of Acceptance. 3. Spare parts must be available in case of immediate repair within the warranty period. 4. If equipment is inoperable and malfunctioning, the winning bidder shall provide maintenance service to the site within seventy two (72) hours after receipt of notification within warranty period.									
	GENERAL REQUIREMENTS:									
	ISO COMPLIANCE ISO 9001:2015 and ISO 14001:2015 Standards CE Conformity; Generator Set passed European or US Manufacturing Standard									
	MAINTENANCE									

	The supplier shall provide quarterly preventive maintenance service within 2-year warranty period.																									
	TRAINING / SEMINAR The Supplier must conduct a Generator Set Unit Orientation and Preventive Maintenance Seminar.																									
	PROVISIONS a.) Set of Tools, Operating and Parts Manual. b.) Initial diesel in tank for testing, upon delivery of Generator Set. c.) Provision of anti-vibration rubber or platform for free to PMOs/TMOs without existing pedestal. d.) Complete installation of Generator Sets, ATS, Breakers, High Amperage Cables, Synchronizing Panel(PMO-Socsargen), Terminal lugs, Solderless Connectors, Copper Bus Bar, Pipe/Conduits and other accessories with testing and commissioning of forty two (42) Units per PMOs as follows;																									
	<table><tr><th colspan="5">Item Description</th></tr><tr><th></th><th>PMO</th><th>Capacity (Standby Power)</th><th>Deployment</th><th>Major Components, 100% Copper High Amperage Cabling Requirements and Other Accessories</th></tr><tr><td rowspan="3">1</td><td rowspan="3">Zamboanga</td><td>75KVA, 230V-1 unit</td><td>Port of Ipil TMO Zamboanga Sibugay</td><td>Free Standing ATS-200Amps, 35mm²-195A@720mtrs., Wall Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors</td></tr><tr><td>75KVA, 230V-1 unit</td><td>Port of Malangas, TMO Zamboanga Sibugay</td><td>Free Standing ATS-200Amps,35mm²-195A:@1,170mtrs.,Wal l Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors</td></tr><tr><td>75KVA, 230V-1 unit</td><td>Port of Margosatubig, TMO Zamboanga del Sur</td><td>Free Standing ATS-200Amps, 35mm²-195A@770mtrs., Wall Mounted Air Circuit Breaker 200A 2P , Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors</td></tr></table>				Item Description						PMO	Capacity (Standby Power)	Deployment	Major Components, 100% Copper High Amperage Cabling Requirements and Other Accessories	1	Zamboanga	75KVA, 230V-1 unit	Port of Ipil TMO Zamboanga Sibugay	Free Standing ATS-200Amps, 35mm ² -195A@720mtrs., Wall Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors	75KVA, 230V-1 unit	Port of Malangas, TMO Zamboanga Sibugay	Free Standing ATS-200Amps,35mm ² -195A:@1,170mtrs.,Wal l Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors	75KVA, 230V-1 unit	Port of Margosatubig, TMO Zamboanga del Sur	Free Standing ATS-200Amps, 35mm ² -195A@770mtrs., Wall Mounted Air Circuit Breaker 200A 2P , Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
Item Description																										
	PMO	Capacity (Standby Power)	Deployment	Major Components, 100% Copper High Amperage Cabling Requirements and Other Accessories																						
1	Zamboanga	75KVA, 230V-1 unit	Port of Ipil TMO Zamboanga Sibugay	Free Standing ATS-200Amps, 35mm ² -195A@720mtrs., Wall Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors																						
		75KVA, 230V-1 unit	Port of Malangas, TMO Zamboanga Sibugay	Free Standing ATS-200Amps,35mm ² -195A:@1,170mtrs.,Wal l Mounted Air Circuit Breaker 200A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors																						
		75KVA, 230V-1 unit	Port of Margosatubig, TMO Zamboanga del Sur	Free Standing ATS-200Amps, 35mm ² -195A@770mtrs., Wall Mounted Air Circuit Breaker 200A 2P , Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors																						

2	Masbate	10KVA-1 unit	TMO San Pascual	Wall Mounted ATS-25Amps, 10mm ² -93A@247mtrs., Wall Mounted Circuit Breaker 25A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		10KVA-1 unit	Port of Aroroy	Wall mounted ATS-25Amps, 10mm ² -93A@247mtrs., Wall Mounted Air Circuit Breaker 25A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		150KVA, 3 Phase-1 unit	Baseport	Free Standing ATS-400Amps, 120mm ² -430A@231mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		10KVA-1 unit	Port of Claveria	Wall mounted ATS-25Amps, 10mm ² -93A@154mtrs., Wall Mounted Air Circuit Breaker 25A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		500KVA, 3 Phase-1 unit	POB Port of Ormoc	Free Standing ATS-1250Amps, 240mm ² -680A@423mtrs., Free Standing Air Circuit Breaker 1250A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
3	Western Leyte / Biliran	200KVA, 3 Phase-1 unit	POB Port of Maasin	Free Standing ATS-600Amps, 185mm ² -570A@362mtrs., Wall Mounted Air Circuit Breaker 600A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		200KVA, 3 Phase-1 unit	POB Port of Palompon	Free Standing ATS-600Amps, 185mm ² -570A@385mtrs., Wall Mounted Air Circuit Breaker 600A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		30KVA, 2 Phase-1 unit	TMO Isabel	Free Standing ATS-100Amps, 25mm ² -155A@175mtrs., Wall Mounted Air Circuit

					Breaker 100A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
4	DAVAO	150KVA,3 Phase-1 unit	TMO Babak		Free Standing ATS- 400Amps, 120mm²- 430A@4,985mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		150KVA,3 Phase-1 unit	TMO Malalag		Free Standing ATS- 400Amps, 120mm²- 430A@4,985mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		150KVA,3 Phase-1 unit	TMO Mati		Free Standing ATS- 400Amps, 120mm²- 430A@4,985mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
5	Surigao	50KVA,3 Phase-1 unit	TMO Siargao		Free Standing ATS- 150Amps, 25mm²- 155A@923mtrs., Wall Mounted Air Circuit Breaker 150A 2P, Complete Set of Copper Grounding , Pure copper terminal lugs long barrel and Solderless connectors
		50KVA,3 Phase-1 unit	TMO Lipata		Free Standing ATS- 150Amps, 25mm²- 155A@693mtrs., Wall Mounted Air Circuit Breaker 150A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors

6	Misamis Oriental/ Cagayan de Oro	300KVA,3 Phase-1 unit	TMO Balingoan		Free Standing ATS- 800Amps, 120mm²(Bundle)- 430A@2,770mtrs., Wall Mounted Air Circuit Breaker 800A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
		200KVA,3 Phase-1 unit	TMO Opol		Free Standing ATS- 600Amps, 185mm²- 570A@2,770mtrs., Wall Mounted Air Circuit Breaker 600A 3P,

					Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
7	Misamis Occidental/Ozamis	75KVA-1 unit	TMO Jimenez		Free Standing ATS-200Amps, 35mm ² . Mounted Air Circuit Breaker 200A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
8	NCR North	50KVA-3 Phase-1 unit	TMO Vitas		Free Standing ATS-150Amps, 25mm ² . Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
9	Marquez	250KVA-1 unit	Port of Bulacan		Free Standing ATS-800Amps, 120mm ² (Bundle)-430A@370mtrs., Wall Mounted Air Circuit Breaker 800A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
		150KVA-1 unit	Port of Cavite		Free Standing ATS-400Amps, 120mm ² . 430A@923mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
10	Bataan/Aurora	50KVA,3 Phase-1 unit	Port of Dingalan, Aurora		Free Standing ATS-150Amps, 25mm ² . 155A@347mtrs., Wall Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
11	Northern Luzon	35KVA-1 unit	Port of Claveria, Cagayan		Free Standing ATS-100Amps, 16mm ² . 120A@185mtrs., Wall Mounted Air Circuit Breaker 100A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors	
12	Eastern Leyte/Samar	10KVA,3 Phase-1 unit	TMO Borongan		Wall mounted ATS-25Amps, 10mm ² . 93A@323mtrs., Wall Mounted Air Circuit Breaker 25A 2P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel	

					copper terminal lugs long barrel / copper bus bars and Solderless connectors	
15	Bicol	250KVA,3 Phase-1 unit	TMO Matnog	Free Standing AIS-627Amps, 240mm ² -680A@693mtrs., Wall Mounted Air Circuit Breaker 627A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
16	Batangas	50KVA,3 Phase-1 unit	Port of San Juan	Free Standing AIS-150Amps, 25mm ² -155A@508mtrs., Wall Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
		50 KVA-1 unit	Port of Calatagan	Free Standing AIS-150Amps, 25mm ² -155A@600mtrs., Wall Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
		50KVA-1 unit	Port of Nasugbu	Free Standing AIS-150Amps, 25mm ² -155A@450mtrs., Wall Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
		50KVA-1 unit	Port of Ambulong	Free Standing AIS-150Amps, 25mm ² -155A@323mtrs., Wall Mounted Air Circuit Breaker 150A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
17	Negros Oriental/ Siquijor	200KVA,3 Phase-1 unit	PTB of Dumaguete	Free Standing AIS-600Amps, 185mm ² -570A@523mtrs., Wall Mounted Air Circuit Breaker 600A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors		
		500KVA,3 Phase-1 unit	POB of Dumaguete	Free Standing AIS-1250Amps, 240mm ² (Bundle)-680A@673mtrs., Wall Mounted Air Circuit Breaker 1250A 3P, Complete Set of Copper Grounding, Pure copper		

			terminal lugs long barrel and Solderless connectors
	150KVA,3 Phase-1 unit	PTB, Port of Larena	Free Standing ATS-400Amps, 120mm ² -430A@692mtrs., Wall Mounted Air Circuit Breaker 400A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
	100KVA,3 Phase-1 unit	PTB, Port of Lazi	Free Standing ATS-250Amps, 70mm ² -295A@693mtrs., Wall Mounted Air Circuit Breaker 250A 3P, Complete Set of Copper Grounding, Pure copper terminal lugs long barrel and Solderless connectors
TOTAL NO. OF UNITS : 42			

<p>OTHER REQUIREMENTS</p> <p>Copies of the following documents must be submitted as part of the technical component:</p> <p>a. For Generator Manufacturer:</p> <ul style="list-style-type: none"> a.) Certificate of Manufacturer b.) Certificate of Product Origin c.) Certificate of Distributorship with two (2) years validity from date of bidding (in line with PPA required Warranty) d.) Certificate of Factory Coupling 60 days fresh from Manufacturing e.) Standard Certificates – ISO9001:2015 , ISO14001:2015 and CE Certificate of Conformity that Generator Set passed EU or US Standard. f.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Engine g.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Controller h.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Alternator i.) Certificate of Availability of Authorized Service Center (in the Philippines) with two (2) years
--

	<p>validity from the date of bidding (in line with PPA required Warranty)</p> <p>b. For High Amperage Cable Manufacturer:</p> <p>a.) Standard Certificates – ISO9001:2015 , ISO14001:2015 and ISO18001:2007</p> <p>The original copy of these documents with Red Ribbon shall be submitted during bid opening in a separate envelope.</p>	
	<p>TESTING</p> <p>The equipment shall be tested (on/off and running for at least 10 minutes) after installation to the respective PMOs as per deployment list.</p>	