



**SUPPLEMENTAL/BID BULLETIN NO. 1**

**SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF 43 UNITS  
GENERATOR SETS FOR PORT MANAGEMENT OFFICES (PMOs)**

**T O :** All Prospective Bidders  
:  
Members, HO-BAC-PGCS  
:  
Others Concerned

Relative to the Bidding Documents for the Supply, Delivery, Installation, Testing and Commissioning of 43 Units Generator Sets for Port Management Offices (PMOs) (BAC PGCS-029-2022), which was posted in the PhilGEPS and PPA Websites on 21 February 2022, please be informed of the following amendments thereto, as follows:

**I. ON THE TERMS OF REFERENCE (TOR):**

xxx xxx xxx

**IX. GENERAL REQUIREMENTS**

xxx xxx xxx

**4. Provisions**

xxx xxx xxx

Item Description				
xxx	xxx	xxx		
5	Bohol	xxx	xxx	xxx
		250 KVA, 3 Phase	TMO Jagna	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @630A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @720mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		xxx	xxx	xxx

6	Surigao	xxx    xxx    xxx		
		25KVA, 3 Phase	Port of Sta. Monica	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @100A 3P, 25mm <sup>2</sup> -155A High Amperage Copper Stranded @660mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
TOTAL NO. OF UNITS		18		

**X. OTHER REQUIREMENTS**

xxx    xxx    xxx

**a. For Generator Manufacturer:**

- a.) If the Supplier is the Manufacturer, only the Certificate of Manufacturer must be submitted. If the Supplier is a Distributor, both Certificates of Manufacturer and Distributorship must be submitted.
  - a.1) Certificate of Distributorship (at least 2 years validity from date of opening of bids)
  - a.2) Certificate of Manufacturer
- b.) Certificate of Product Origin
- c.) Certificate of Factory Coupling 60 days fresh from Manufacturing
- d.) Standard Certificates – ISO9001:2015, ISO14001:2015 and CE Certificate of Conformity that Generator Set passed EU or US Standard.
- e.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Engine
- f.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Controller
- g.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Alternator
- h.) Certificate of Availability of Service Center (at least 2 years validity from date of opening of bids)

xxx    xxx    xxx

## II. ON THE TECHNICAL SPECIFICATIONS:

xxx xxx xxx

### GENERAL REQUIREMENTS

xxx xxx xxx

#### 3. Provisions

xxx xxx xxx

Item Description				
XXX    XXX    XXX				
5	Bohol	XXX    XXX    XXX		
		250 KVA, 3 Phase	TMO Jagna	Free Standing ATS and Floor Standing Air Circuit Breaker with NEMA Enclosure @630A 3P, 240mm <sup>2</sup> -680A High Amperage Copper Stranded @720mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
		XXX    XXX    XXX		
6	Surigao	XXX    XXX    XXX		
		25KVA, 3 Phase	Port of Sta. Monica	Free Standing ATS and Wall Mounted Main Circuit Breaker with NEMA Enclosure @100A 3P, 25mm <sup>2</sup> -155A High Amperage Copper Stranded @660mtrs, Complete set of Copper grounding, pure copper terminal lug long barrel and solderless connector
TOTAL NO. OF UNITS		18		



## OTHER REQUIREMENTS

xxx    xxx    xxx

### **A. For Generator Manufacturer:**


- a.) If the Supplier is the Manufacturer, only the Certificate of Manufacturer must be submitted. If the Supplier is a Distributor, both Certificates of Manufacturer and Distributorship must be submitted.
  - a.1) Certificate of Distributorship (at least 2 years validity from date of opening of bids)
  - a.2) Certificate of Manufacturer
- b.) Certificate of Product Origin
- c.) Certificate of Factory Coupling 60 days fresh from Manufacturing
- d.) Standard Certificates – ISO9001:2015, ISO14001:2015 and CE Certificate of Conformity that Generator Set passed EU or US Standard.
- e.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Engine
- f.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Controller
- g.) Certificate – Current Original Equipment Manufacturer (OEM) License of Generator Set Alternator
- h.) Certificate of Availability of Service Center (at least 2 years validity from date of opening of bids)

xxx    xxx    xxx

Issued this 7<sup>th</sup> day of March 2022.

THE BIDS AND AWARDS COMMITTEE:

By:

  
**MARK JON S. PALOMAR**  
Chairperson, HO-BAC-PGCS