

SUPPLEMENTAL/BID BULLETIN NO. 1

SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF LED SOLAR STREET/ROAD LIGHTS FOR PORT MANAGEMENT OFFICES

TO

All Prospective Bidders

Members, HO-BAC-PGCS

Others Concerned

Relative to the Bidding Documents for the Supply, Delivery, Installation, Testing and Commissioning of LED Solar Street/Road Lights for Port Management Offices (BAC PGCS-197-2020), which was posted in the PhilGEPS and PPA Websites on 26 November 2020, please be informed of the following amendments thereto, as follows:

I. ON THE TERMS OF REFERENCE (TOR):

- V. A. Technical Specifications LED Solar Street/Road Lights
 - 4. Controller

Specification: 12V 100W Human body induction, Protection Grade: IP65 or Adjust Time: First 4 hours: 60W, Seconds 4 hours: 40W and Third 4 hours: 20W, Protection Grade: IP65

II. ON THE TECHNICAL SPECIFICATIONS:

Technical Specifications:

4. Controller

Specification: 12V 100W Human body induction, Protection Grade: IP65 or Adjust Time: First 4 hours: 60W, Seconds 4 hours: 40W and Third 4 hours: 20W, Protection Grade: IP65

Issued this 9th day of December 2020

THE BIDS AND AWARDS COMMITTEE:

By:

MARK JON S. PALOMAR Chairperson, HO-BAC-PGCS