

Technical Specifications

Item	Specification	Statement of Compliance
1	<p>Four (4) Units Air Curtain, Branded, High Quality with additional specs:</p> <ul style="list-style-type: none"> • Air flow volume: 1200 CFM • Sound Pressure Level: 59 dB or less • Unit Dimension: 902mm X 220mm X 220mm <p>Should have service center located within Dapitan/Dipolog City.</p>	<p>Bidders must state here either “Comply” or “Not Comply” against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in a Bidders Bid and cross-referenced to that evidence.</p>
2	<p>Two (2) Units Air Curtain, Branded, High Quality with additional specs:</p> <ul style="list-style-type: none"> • Air flow volume: 1650 CFM • Sound Pressure Level: 61 dB or less • Unit Dimension: 1202mm X 220mm X 220mm <p>Should have service center located within Dapitan/Dipolog City.</p>	<p>Evidence shall be in the form of manufacturer’s un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate.</p>
3	<p>Three (3) units 1 HP Split Type Air conditioning unit, Inverter Technology, Branded, High Quality with additional specs and features:</p> <ul style="list-style-type: none"> • Rated Cooling Capacity (Max-Min): 10,200 (13,000-2,457) BTU/h • Refrigerant: R410A • Indoor Noise Level (Hi/Mi/Lo): 40/36/31 or less • Max Refrigerant Pipe Length (m): 25 or longer • With Timer • Sleep Mode <p>Should have service center located within Dapitan/Dipolog City.</p>	<p>A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the</p>